

# CHAPTER 3

## OCCUPANCY CLASSIFICATION AND USE

---

**User note:**

*About this chapter:* Chapter 3 provides the criteria by which buildings and structures are classified into use groups and occupancies. Through the balance of the code, occupancy classification is fundamental in the setting of features of construction; occupant safety requirements, especially building limitations; means of egress; fire protection systems; and interior finishes.

---

### SECTION 301 SCOPE

**301.1 General.** The provisions of this chapter shall control the classification of all buildings and structures as to occupancy and use. Different classifications of occupancy and use represent varying levels of hazard and risk to building occupants and adjacent properties.

### SECTION 302 OCCUPANCY CLASSIFICATION AND USE DESIGNATION

**302.1 Occupancy classification.** Occupancy classification is the formal designation of the primary purpose of the building, structure or portion thereof. Structures shall be classified into one or more of the occupancy groups specified in this section based on the nature of the hazards and risks to building occupants generally associated with the intended purpose of the building or structure. An area, room or space that is intended to be occupied at different times for different purposes shall comply with all applicable requirements associated with such potential multipurpose. Structures containing multiple occupancy groups shall comply with Section 508. Where a structure is proposed for a purpose that is not specified in this section, such structure shall be classified in the occupancy it most nearly resembles based on the fire safety and relative hazard. Occupied roofs shall be classified in the group that the occupancy most nearly resembles, according to the fire safety and relative hazard, and shall comply with Section 503.1.4 .

1. Assembly (see Section 303): Groups A-1, A-2, A-3, A-4 and A-5.
2. Business (see Section 304): Group B.
3. Educational (see Section 305): Group E.
4. Factory and Industrial (see Section 306): Groups F-1 and F-2.
5. High Hazard (see Section 307): Groups H-1, H-2, H-3, H-4 and H-5.
6. Institutional (see Section 308): Groups I-1, I-2, I-3 and I-4.
7. Mercantile (see Section 309): Group M.
8. Residential (see Section 310): Groups R-1, R-2, R-3 and R-4.

9. Storage (see Section 311): Groups S-1 and S-2.

10. Utility and Miscellaneous (see Section 312): Group U.

**302.2 Use designation.** Occupancy groups contain subordinate uses having similar hazards and risks to building occupants. Uses include, but are not limited to, those functional designations specified within the occupancy group descriptions in Section 302.1. Certain uses require specific limitations and controls in accordance with the provisions of Chapter 4 and elsewhere in this code.

### SECTION 303 ASSEMBLY GROUP A

**303.1 Assembly Group A.** Assembly Group A occupancy includes, among others, the use of a building or structure, or a portion thereof, for the gathering of persons for purposes such as civic, social or religious functions; recreation, food or drink consumption or awaiting transportation.

**303.1.1 Small buildings and tenant spaces.** A building or tenant space used for assembly purposes with an *occupant load* of less than 50 persons shall be classified as a Group B occupancy.

**303.1.2 Small assembly spaces.** The following rooms and spaces shall not be classified as Assembly occupancies:

1. A room or space used for assembly purposes with an *occupant load* of less than 50 persons and accessory to another occupancy shall be classified as a Group B occupancy or as part of that occupancy.
2. A room or space used for assembly purposes that is less than 750 square feet (70 m<sup>2</sup>) in area and accessory to another occupancy shall be classified as a Group B occupancy or as part of that occupancy.

**303.1.3 Associated with Group E occupancies.** A room or space used for assembly purposes that is associated with a Group E occupancy is not considered a separate occupancy.

**303.1.4 Accessory to places of religious worship.** Accessory religious educational rooms and religious auditoriums with *occupant loads* of less than 100 per room or space are not considered separate occupancies.

**303.1.5 Special amusement areas.** *Special amusement areas* shall comply with Section 411.

**303.2 Assembly Group A-1.** Group A-1 occupancy includes assembly uses, usually with fixed seating, intended for the production and viewing of the performing arts or motion pictures including, but not limited to:

- Motion picture theaters
- Symphony and concert halls
- Television and radio studios admitting an audience
- Theaters

**303.3 Assembly Group A-2.** Group A-2 occupancy includes assembly uses intended for food and/or drink consumption including, but not limited to:

- Banquet halls
- Casinos (*gaming areas*)
- Nightclubs
- Restaurants, cafeterias and similar dining facilities (including associated commercial kitchens)
- Taverns and bars

**303.4 Assembly Group A-3.** Group A-3 occupancy includes assembly uses intended for worship, recreation or amusement and other assembly uses not classified elsewhere in Group A including, but not limited to:

- Amusement arcades
- Art galleries more than 3,000 square feet (279 m<sup>2</sup>)
- Bowling alleys
- Community halls
- Courtrooms
- Dance halls (not including food or drink consumption)
- Exhibition halls
- Funeral parlors
- Greenhouses* for the conservation and exhibition of plants that provide public access
- Gymnasiums (without spectator seating)
- Indoor *swimming pools* (without spectator seating)
- Indoor tennis courts (without spectator seating)
- Lecture halls
- Libraries
- Museums
- Places of religious worship*
- Pool and billiard parlors
- Waiting areas in transportation terminals

**303.5 Assembly Group A-4.** Group A-4 occupancy includes assembly uses intended for viewing of indoor sporting events and activities with spectator seating including, but not limited to:

- Arenas
- Skating rinks
- Swimming pools*
- Tennis courts

**303.6 Assembly Group A-5.** Group A-5 occupancy includes assembly uses intended for participation in or viewing outdoor activities including, but not limited to:

- Amusement park structures
- Bleachers*
- Grandstands*
- Stadiums

## SECTION 304 BUSINESS GROUP B

**304.1 Business Group B.** Business Group B occupancy includes, among others, the use of a building or structure, or a portion thereof, for office, professional or service-type transactions, including storage of records and accounts. Business occupancies shall include, but not be limited to, the following:

- Airport traffic control towers
- Ambulatory care facilities*
- Animal hospitals, kennels and pounds
- Banks
- Barber and beauty shops
- Car wash
- Civic administration
- Clinic, outpatient*
- Dry cleaning and laundries: pick-up and delivery stations and self-service
- Educational occupancies for students above the 12th grade including *higher education laboratories*
- Electronic data processing
- Food processing establishments and commercial kitchens not associated with restaurants, cafeterias and similar dining facilities not more than 2,500 square feet (232 m<sup>2</sup>) in area
- Laboratories: testing and research
- Motor vehicle showrooms
- Post offices
- Print shops
- Professional services (architects, attorneys, dentists, physicians, engineers, etc.)
- Radio and television stations
- Telephone exchanges
- Training and skill development not in a school or academic program (this shall include, but not be limited to, tutoring centers, martial arts studios, gymnastics and similar uses regardless of the ages served, and where not classified as a Group A occupancy)

**304.2 Airport traffic control towers.** Airport traffic control towers shall comply with Section 412.2.

**304.3 Ambulatory care facilities.** *Ambulatory care facilities* shall comply with Section 422.

**304.4 Higher education laboratories.** *Higher education laboratories* shall comply with Section 428.

### SECTION 305 EDUCATIONAL GROUP E

**305.1 Educational Group E.** Educational Group E occupancy includes, among others, the use of a building or structure, or a portion thereof, by six or more persons at any one time for educational purposes through the 12th grade.

**305.1.1 Accessory to places of religious worship.** Religious educational rooms and religious auditoriums, which are accessory to *places of religious worship* in accordance with Section 303.1.4 and have *occupant loads* of less than 100 per room or space, shall be classified as Group A-3 occupancies.

**305.2 Group E, day care facilities.** This group includes buildings and structures or portions thereof occupied by more than five children older than 2½ years of age who receive educational, supervision or *personal care services* for fewer than 24 hours per day.

**305.2.1 Within places of religious worship.** Rooms and spaces within *places of religious worship* providing such day care during religious functions shall be classified as part of the primary occupancy.

**305.2.2 Five or fewer children.** A facility having five or fewer children receiving such day care shall be classified as part of the primary occupancy.

**305.2.3 Five or fewer children in a dwelling unit.** A facility such as the above within a *dwelling unit* and having five or fewer children receiving such day care shall be classified as a Group R-3 occupancy or shall comply with the *International Residential Code*.

**305.2.4 Family home child care.** Family home child care licensed by Washington state for the care of twelve or fewer children shall be classified as Group R-3 or shall comply with the *International Residential Code*.

**305.3 Storm shelters in Group E occupancies.** *Storm shelters* shall be provided for Group E occupancies where required by Section 423.5.

### SECTION 306 FACTORY GROUP F

**306.1 Factory Industrial Group F.** Factory Industrial Group F occupancy includes, among others, the use of a building or structure, or a portion thereof, for assembling, disassembling, fabricating, finishing, manufacturing, packaging, repair or processing operations that are not classified as a Group H hazardous or Group S storage occupancy.

**306.2 Moderate-hazard factory industrial, Group F-1.** Factory industrial uses that are not classified as Factory Industrial F-2 Low Hazard shall be classified as F-1 Moderate Hazard and shall include, but not be limited to, the following:

Aircraft (manufacturing, not to include repair)

Appliances  
Athletic equipment  
Automobiles and other motor vehicles  
Bakeries  
Beverages: over 16-percent alcohol content  
Bicycles  
Boats  
Brooms or brushes  
Business machines  
Cameras and photo equipment  
Canvas or similar fabric  
Carpets and rugs (includes cleaning)  
Clothing  
Construction and agricultural machinery  
Disinfectants  
Dry cleaning and dyeing  
Electric generation plants  
Electronics  
Energy storage systems (ESS) in dedicated use buildings  
Engines (including rebuilding)  
Food processing establishments and commercial kitchens not associated with restaurants, cafeterias and similar dining facilities more than 2,500 square feet (232 m<sup>2</sup>) in area  
Furniture  
Hemp products  
Jute products  
Laundries  
Leather products  
Machinery  
Marijuana processing  
Metals  
Millwork (sash and door)  
Motion pictures and television filming (without spectators)  
Musical instruments  
Optical goods  
Paper mills or products  
Photographic film  
Plastic products  
Printing or publishing  
Recreational vehicles  
Refuse incineration  
Shoes  
Soaps and detergents  
Textiles  
Tobacco  
Trailers

- Upholstering
- Water/sewer treatment facilities
- Wood; distillation
- Woodworking (cabinet)

**306.2.1 Aircraft manufacturing facilities.** Aircraft manufacturing facilities shall comply with Section 412.6.

**306.3 Low-hazard factory industrial, Group F-2.** Factory industrial uses that involve the fabrication or manufacturing of noncombustible materials that during finishing, packing or processing do not involve a significant fire hazard shall be classified as F-2 occupancies and shall include, but not be limited to, the following:

- Beverages: up to and including 16-percent alcohol content
- Brick and masonry
- Ceramic products
- Foundries
- Glass products
- Gypsum
- Ice
- Metal products (fabrication and assembly)

**SECTION 307  
HIGH-HAZARD GROUP H**

**[F] 307.1 High-hazard Group H.** High-hazard Group H occupancy includes, among others, the use of a building or structure, or a portion thereof, that involves the manufacturing, processing, generation or storage of materials that constitute a physical or *health hazard* in quantities in excess of those allowed in *control areas* complying with Section 414, based on the maximum allowable quantity limits for *control areas* set forth in Tables 307.1(1) and 307.1(2). Hazardous occupancies are classified in Groups H-1, H-2, H-3, H-4 and H-5 and shall be in accordance with this section, the requirements of Section 415 and the *International Fire Code*. *Hazardous materials* stored, or used on top of roofs or canopies, shall be classified as outdoor storage or use and shall comply with the *International Fire Code*.

**[F] 307.1.1 Uses other than Group H.** An occupancy that stores, uses or handles *hazardous materials* as described in one or more of the following items shall not be classified as Group H, but shall be classified as the occupancy that it most nearly resembles.

1. Buildings and structures occupied for the application of flammable finishes, provided that such buildings or areas conform to the requirements of Section 416 and the *International Fire Code*.
2. Wholesale and retail sales and storage of flammable and combustible liquids in mercantile occupancies conforming to the *International Fire Code*.

3. Closed piping system containing *flammable or combustible liquids* or gases utilized for the operation of machinery or equipment.
4. Cleaning establishments that utilize *combustible liquid* solvents having a *flash point* of 140°F (60°C) or higher in closed systems employing equipment *listed* by an *approved* testing agency, provided that this occupancy is separated from all other areas of the building by 1-hour *fire barriers* constructed in accordance with Section 707 or 1-hour *horizontal assemblies* constructed in accordance with Section 711, or both.
5. Cleaning establishments that utilize a liquid solvent having a *flash point* at or above 200°F (93°C).
6. Liquor stores and distributors without bulk storage.
7. Refrigeration systems.
8. The storage or utilization of materials for agricultural purposes on the premises.
9. Stationary storage battery systems installed in accordance with the *International Fire Code*.
10. *Corrosive* personal or household products in their original packaging used in retail display.
11. Commonly used *corrosive* building materials.
12. Buildings and structures occupied for *aerosol product* storage, aerosol cooking spray products or plastic aerosol 3 products shall be classified as Group S-1, provided that such buildings conform to the requirements of the *International Fire Code*.
13. Display and storage of nonflammable solid and nonflammable or noncombustible liquid *hazardous materials* in quantities not exceeding the maximum allowable quantity per *control area* in Group M or S occupancies complying with Section 414.2.5.
14. The storage of black powder, smokeless propellant and small arms primers in Groups M and R-3 and special industrial *explosive* devices in Groups B, F, M and S, provided such storage conforms to the quantity limits and requirements prescribed in the *International Fire Code*.
15. Stationary fuel cell power systems installed in accordance with the *International Fire Code*.
16. Capacitor energy storage systems in accordance with the *International Fire Code*.
17. Group B *higher education laboratory* occupancies complying with Section 428 and Chapter 38 of the *International Fire Code*.
18. Distilling or brewing of beverages conforming to the requirements of the *International Fire Code*.
19. The storage of beer, distilled spirits and wines in barrels and casks conforming to the requirements of the *International Fire Code*.

**TABLE 307.1(1)**  
**MAXIMUM ALLOWABLE QUANTITY PER CONTROL AREA OF HAZARDOUS MATERIALS POSING A PHYSICAL HAZARD<sup>a, j, m, n, p</sup>**

| MATERIAL                                   | CLASS              | GROUP WHEN THE MAXIMUM ALLOWABLE QUANTITY IS EXCEEDED | STORAGE <sup>b</sup>      |                         |                         | USE-CLOSED SYSTEMS <sup>b</sup> |                         |                         | USE-OPEN SYSTEMS <sup>b</sup> |                         |
|--|--------------------|---|---------------------------|-------------------------|-------------------------|---------------------------------|-------------------------|-------------------------|-------------------------------|-------------------------|
|  |                    |   | Solid pounds (cubic feet) | Liquid gallons (pounds) | Gas (cubic feet at NTP) | Solid pounds (cubic feet)       | Liquid gallons (pounds) | Gas (cubic feet at NTP) | Solid pounds (cubic feet)     | Liquid gallons (pounds) |
| Combustible dust                           | NA                 | H-2   | See Note q                | NA                      | NA                      | See Note q                      | NA                      | NA                      | See Note q                    | NA                      |
| Combustible fiber <sup>d</sup>             | Loose              | H-3   | (100)                     | NA                      | NA                      | (100)                           | NA                      | NA                      | (20)                          | NA                      |
|  | Baled <sup>o</sup> |   | (1,000)                   |                         |                         | (1,000)                         |                         |                         | (200)                         |                         |
| Combustible liquid <sup>e, i</sup>         | II                 | H-2 or H-3  | NA                        | 120 <sup>d, e</sup>     | NA                      | NA                              | NA                      | NA                      | NA                            | 30 <sup>d</sup>         |
|  | IIIA               | H-2 or H-3  |                           | 330 <sup>d, e</sup>     |                         |                                 |                         |                         |                               | 80 <sup>d</sup>         |
|  | IIIB               | NA  |                           | 13,200 <sup>e, f</sup>  |                         |                                 |                         |                         |                               | 3,300 <sup>f</sup>      |
| Cryogenic flammable                        | NA                 | H-2   | NA                        | 45 <sup>d</sup>         | NA                      | NA                              | 45 <sup>d</sup>         | NA                      | NA                            | 10 <sup>d</sup>         |
| Cryogenic inert                            | NA                 | NA  | NA                        | NA                      | NL                      | NA                              | NA                      | NL                      | NA                            | NA                      |
| Cryogenic oxidizing                        | NA                 | H-3   | NA                        | 45 <sup>d</sup>         | NA                      | NA                              | 45 <sup>d</sup>         | NA                      | NA                            | 10 <sup>d</sup>         |
| Explosives                                 | Division 1.1       | H-1   | 1 <sup>e, g</sup>         | (1) <sup>e, g</sup>     | NA                      | 0.25 <sup>g</sup>               | (0.25) <sup>g</sup>     | NA                      | 0.25 <sup>g</sup>             | (0.25) <sup>g</sup>     |
|  | Division 1.2       | H-1   | 1 <sup>e, g</sup>         | (1) <sup>e, g</sup>     |                         | 0.25 <sup>g</sup>               | (0.25) <sup>g</sup>     |                         | 0.25 <sup>g</sup>             | (0.25) <sup>g</sup>     |
|  | Division 1.3       | H-1 or H-2  | 5 <sup>e, g</sup>         | (5) <sup>e, g</sup>     |                         | 1 <sup>g</sup>                  | (1) <sup>g</sup>        |                         | 1 <sup>g</sup>                | (1) <sup>g</sup>        |
|  | Division 1.4       | H-3   | 50 <sup>e, g</sup>        | (50) <sup>e, g</sup>    |                         | 50 <sup>g</sup>                 | (50) <sup>g</sup>       |                         | NA                            | NA                      |
|  | Division 1.4G      | H-3   | 125 <sup>e, 1</sup>       | NA                      |                         | NA                              | NA                      |                         | NA                            | NA                      |
|  | Division 1.5       | H-1   | 1 <sup>e, g</sup>         | (1) <sup>e, g</sup>     |                         | 0.25 <sup>g</sup>               | (0.25) <sup>g</sup>     |                         | 0.25 <sup>g</sup>             | (0.25) <sup>g</sup>     |
|  | Division 1.6       | H-1   | 1 <sup>e, g</sup>         | NA                      |                         | NA                              | NA                      |                         | NA                            | NA                      |
| Flammable gas                              | Gaseous            | H-2   | NA                        | NA                      | 1,000 <sup>d, e</sup>   | NA                              | NA                      | 1,000 <sup>d, e</sup>   | NA                            | NA                      |
|  | Liquefied          |   |                           | (150) <sup>d, e</sup>   | NA                      |                                 | (150) <sup>d, e</sup>   | NA                      |                               |                         |
| Flammable liquid <sup>c</sup>              | IA                 | H-2 or H-3  | NA                        | 30 <sup>d, e</sup>      | NA                      | NA                              | NA                      | NA                      | NA                            | 10 <sup>d</sup>         |
|  | IB and IC          |   |                           | 120 <sup>d, e</sup>     |                         |                                 |                         |                         |                               | 30 <sup>d</sup>         |
| Flammable liquid, combination (IA, IB, IC) | NA                 | H-2 or H-3  | NA                        | 120 <sup>d, e, h</sup>  | NA                      | NA                              | 120 <sup>d, h</sup>     | NA                      | NA                            | 30 <sup>d, h</sup>      |
| Flammable solid                            | NA                 | H-3   | 125 <sup>d, e</sup>       | NA                      | NA                      | 125 <sup>d</sup>                | NA                      | NA                      | 25 <sup>d</sup>               | NA                      |
| Inert gas                                  | Gaseous            | NA  | NA                        | NA                      | NL                      | NA                              | NA                      | NL                      | NA                            | NA                      |
|  | Liquefied          | NA  | NA                        | NA                      | NL                      | NA                              | NA                      | NL                      | NA                            | NA                      |
| Organic peroxide                           | UD                 | H-1   | 1 <sup>e, g</sup>         | (1) <sup>e, g</sup>     | NA                      | 0.25 <sup>g</sup>               | (0.25) <sup>g</sup>     | NA                      | 0.25 <sup>g</sup>             | (0.25) <sup>g</sup>     |
|  | I                  | H-2   | 5 <sup>d, e</sup>         | (5) <sup>d, e</sup>     |                         | 1 <sup>d</sup>                  | (1) <sup>d</sup>        |                         | 1 <sup>d</sup>                | (1) <sup>d</sup>        |
|  | II                 | H-3   | 50 <sup>d, e</sup>        | (50) <sup>d, e</sup>    |                         | 50 <sup>d</sup>                 | (50) <sup>d</sup>       |                         | 10 <sup>d</sup>               | (10) <sup>d</sup>       |
|  | III                | H-3   | 125 <sup>d, e</sup>       | (125) <sup>d, e</sup>   |                         | 125 <sup>d</sup>                | (125) <sup>d</sup>      |                         | 25 <sup>d</sup>               | (25) <sup>d</sup>       |
|  | IV                 | NA  | NL                        | NL                      |                         | NL                              | NL                      |                         | NL                            | NL                      |
|  | V                  | NA  | NL                        | NL                      |                         | NL                              | NL                      |                         | NL                            | NL                      |

(continued)

**TABLE 307.1(1)—continued**  
**MAXIMUM ALLOWABLE QUANTITY PER CONTROL AREA OF HAZARDOUS MATERIALS POSING A PHYSICAL HAZARD<sup>a, j, m, n, p</sup>**

| MATERIAL            | CLASS          | GROUP WHEN THE MAXIMUM ALLOWABLE QUANTITY IS EXCEEDED | STORAGE <sup>b</sup>      |                         |                         | USE-CLOSED SYSTEMS <sup>b</sup> |                         |                         | USE-OPEN SYSTEMS <sup>b</sup> |                         |
|---------------------|----------------|---|---------------------------|-------------------------|-------------------------|---------------------------------|-------------------------|-------------------------|-------------------------------|-------------------------|
|                     |                |   | Solid pounds (cubic feet) | Liquid gallons (pounds) | Gas (cubic feet at NTP) | Solid pounds (cubic feet)       | Liquid gallons (pounds) | Gas (cubic feet at NTP) | Solid pounds (cubic feet)     | Liquid gallons (pounds) |
| Oxidizer            | 4              | H-1   | 1 <sup>g</sup>            | (1) <sup>e, g</sup>     | NA                      | 0.25 <sup>g</sup>               | (0.25) <sup>g</sup>     | NA                      | 0.25 <sup>g</sup>             | (0.25) <sup>g</sup>     |
|                     | 3 <sup>k</sup> | H-2 or H-3  | 10 <sup>d, e</sup>        | (10) <sup>d, e</sup>    |                         | 2 <sup>d</sup>                  | (2) <sup>d</sup>        |                         | 2 <sup>d</sup>                | (2) <sup>d</sup>        |
|                     | 2              | H-3   | 250 <sup>d, e</sup>       | (250) <sup>d, e</sup>   |                         | 250 <sup>d</sup>                | (250) <sup>d</sup>      |                         | 50 <sup>d</sup>               | (50) <sup>d</sup>       |
|                     | 1              | NA  | 4,000 <sup>e, f</sup>     | (4,000) <sup>e, f</sup> |                         | 4,000 <sup>f</sup>              | (4,000) <sup>f</sup>    |                         | 1,000 <sup>f</sup>            | (1,000) <sup>f</sup>    |
| Oxidizing gas       | Gaseous        | H-3   | NA                        | NA                      | 1,500 <sup>d, e</sup>   | NA                              | NA                      | 1,500 <sup>d, e</sup>   | NA                            | NA                      |
|                     | Liquefied      |   |                           | (150) <sup>d, e</sup>   | NA                      |                                 | (150) <sup>d, e</sup>   | NA                      |                               |                         |
| Pyrophoric          | NA             | H-2   | 4 <sup>e, g</sup>         | (4) <sup>e, g</sup>     | 50 <sup>e, g</sup>      | 1 <sup>g</sup>                  | (1) <sup>g</sup>        | 10 <sup>e, g</sup>      | 0                             | 0                       |
| Unstable (reactive) | 4              | H-1   | 1 <sup>e, g</sup>         | (1) <sup>e, g</sup>     | 10 <sup>e, g</sup>      | 0.25 <sup>g</sup>               | (0.25) <sup>g</sup>     | 2 <sup>e, g</sup>       | 0.25 <sup>g</sup>             | (0.25) <sup>g</sup>     |
|                     | 3              | H-1 or H-2  | 5 <sup>d, e</sup>         | (5) <sup>d, e</sup>     | 50 <sup>d, e</sup>      | 1 <sup>d</sup>                  | (1) <sup>d</sup>        | 10 <sup>d, e</sup>      | 1 <sup>d</sup>                | (1) <sup>d</sup>        |
|                     | 2              | H-3   | 50 <sup>d, e</sup>        | (50) <sup>d, e</sup>    | 750 <sup>d, e</sup>     | 50 <sup>d</sup>                 | (50) <sup>d</sup>       | 750 <sup>d, e</sup>     | 10 <sup>d</sup>               | (10) <sup>d</sup>       |
|                     | 1              | NA  | NL                        | NL                      | NL                      | NL                              | NL                      | NL                      | NL                            | NL                      |
| Water reactive      | 3              | H-2   | 5 <sup>d, e</sup>         | (5) <sup>d, e</sup>     | NA                      | 5 <sup>d</sup>                  | (5) <sup>d</sup>        | NA                      | 1 <sup>d</sup>                | (1) <sup>d</sup>        |
|                     | 2              | H-3   | 50 <sup>d, e</sup>        | (50) <sup>d, e</sup>    |                         | 50 <sup>d</sup>                 | (50) <sup>d</sup>       |                         | 10 <sup>d</sup>               | (10) <sup>d</sup>       |
|                     | 1              | NA  | NL                        | NL                      |                         | NL                              | NL                      |                         | NL                            | NL                      |

For SI: 1 cubic foot = 0.028 m<sup>3</sup>, 1 pound = 0.454 kg, 1 gallon = 3.785 L.  
 NL = Not Limited; NA = Not Applicable; UD = Unclassified Detonable.

- a. For use of control areas, see Section 414.2.
- b. The aggregate quantity in use and storage shall not exceed the quantity specified for storage.
- c. The quantities of alcoholic beverages in retail and wholesale sales occupancies shall not be limited provided the liquids are packaged in individual containers not exceeding 1.3 gallons. In retail and wholesale sales occupancies, the quantities of medicines, foodstuffs or consumer products, and cosmetics containing not more than 50 percent by volume of water-miscible liquids with the remainder of the solutions not being flammable, shall not be limited, provided that such materials are packaged in individual containers not exceeding 1.3 gallons.
- d. Maximum allowable quantities shall be increased 100 percent in buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1. Where Note e also applies, the increase for both notes shall be applied accumulatively.
- e. Maximum allowable quantities shall be increased 100 percent when stored in approved storage cabinets, day boxes, gas cabinets, gas rooms or exhausted enclosures or in listed safety cans in accordance with Section 5003.9.10 of the *International Fire Code*. Where Note d also applies, the increase for both notes shall be applied accumulatively.
- f. Quantities shall not be limited in a building equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1.
- g. Allowed only in buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1.
- h. Containing not more than the maximum allowable quantity per control area of Class IA, IB or IC flammable liquids.
- i. The maximum allowable quantity shall not apply to fuel oil storage complying with Section 605.4.2 of the *International Fire Code*.
- j. Quantities in parentheses indicate quantity units in parentheses at the head of each column.
- k. A maximum quantity of 220 pounds of solid or 22 gallons of liquid Class 3 oxidizers is allowed when such materials are necessary for maintenance purposes, operation or sanitation of equipment when the storage containers and the manner of storage are approved.
- l. Net weight of the pyrotechnic composition of the fireworks. Where the net weight of the pyrotechnic composition of the fireworks is not known, 25 percent of the gross weight of the fireworks, including packaging, shall be used.
- m. For gallons of liquids, divide the amount in pounds by 10 in accordance with Section 5003.1.2 of the *International Fire Code*.
- n. For storage and display quantities in Group M and storage quantities in Group S occupancies complying with Section 414.2.5, see Tables 414.2.5(1) and 414.2.5(2).
- o. Densely packed baled cotton that complies with the packing requirements of ISO 8115 shall not be included in this material class.
- p. The following shall not be included in determining the maximum allowable quantities:
  - 1. Liquid or gaseous fuel in fuel tanks on vehicles.
  - 2. Liquid or gaseous fuel in fuel tanks on motorized equipment operated in accordance with the *International Fire Code*.
  - 3. Gaseous fuels in piping systems and fixed appliances regulated by the *International Fuel Gas Code*.
  - 4. Liquid fuels in piping systems and fixed appliances regulated by the *International Mechanical Code*.
  - 5. Alcohol-based hand rubs classified as Class I or II liquids in dispensers that are installed in accordance with Sections 5705.5 and 5705.5.1 of the *International Fire Code*. The location of the alcohol-based hand rub (ABHR) dispensers shall be provided in the construction documents.
- q. Where manufactured, generated or used in such a manner that the concentration and conditions create a fire or explosion hazard based on information prepared in accordance with Section 414.1.3.