

# Chapter 3

## Use and Occupancy Classification

### General Comments

Chapter 3 provides for the classification of buildings, structures and parts thereof based on the purpose or purposes for which they are used.

Section 302 identifies the occupancy groups into which all buildings, structures and parts thereof must be classified.

Sections 303 through 312 identify the occupancy characteristics of each group classification. In some sections, specific group classifications having requirements in common are collectively organized such that one term applies to all. For example, Groups A-1, A-2, A-3, A-4 and A-5 are individual groups. The general term Group A, however, includes each of these individual groups. For this reason, each specific assembly group classification is included in Section 303.

Definitions play a key role in determining the occupancy classification. All definitions are located in Chapter 2. This chapter lists key definitions for classification of occupancies.

In the early years of building code development, the essence of regulatory safeguards from fire was to provide a reasonable level of protection to property. The idea was that if property was adequately protected from fire, then the building occupants would also be protected.

From this outlook on fire safety, the concept of equivalent risk has evolved in the code. This concept maintains that, in part, an acceptable level of risk against the damages of fire respective to a particular occupancy type (group) can be achieved by limiting the height and area of buildings containing such occupancies according to the building's construction type (i.e., its relative fire endurance).

The concept of equivalent risk involves three interdependent considerations: (1) the level of fire hazard associated with the specific occupancy of the facility; (2) the reduction of fire hazard by limiting the floor areas and the height of the building based on the fuel load (combustible contents and burnable building components); and (3) the level of overall fire resistance provided by the type of construction used for the building.

The interdependence of these fire safety considerations can be seen by first looking at Tables 601 and 602, which show the fire-resistance ratings of the principal structural elements comprising a building in relation to the five classifications for types of construction. Type

I construction is the classification that generally requires the highest fire-resistance ratings for structural elements, whereas Type V construction, which is designated as a combustible type of construction, generally requires the least amount of fire-resistance-rated structural elements. If one then looks at Table 503, the relationship among group classification, allowable heights and areas and types of construction becomes apparent. Respective to each group classification, the greater the fire-resistance rating of structural elements, as represented by the type of construction, the greater the floor area and height allowances. The greater the potential fire hazards indicated as a function of the group, the lesser the height and area allowances for a particular construction type.

As a result of extensive research and advancements in fire technology, today's building codes are more comprehensive and complex regulatory instruments than they were in the earlier years of code development. While the principle of equivalent risk remains an important component in building codes, perspectives have changed and life safety is now the paramount fire issue. Even so, occupancy classification still plays a key part in organizing and prescribing the appropriate protection measures. As such, threshold requirements for fire protection and means of egress systems are based on occupancy classification (see Chapters 9 and 10).

Other sections of the code also contain requirements respective to the classification of building groups. For example, Section 102.6 deals with applicability of the code to existing structures; Section 705 deals with requirements for exterior wall fire-resistance ratings that are tied to the occupancy classification of a building and Section 803.9 contains interior finish requirements that are dependent upon the occupancy classification.

### Purpose

The purpose of this chapter is to classify a building, structure or part thereof into a group based on the specific purpose for which it is designed or occupied. Throughout the code, group classifications are considered a fundamental principle in organizing and prescribing the appropriate features of construction and occupant safety requirements for buildings, especially general building limitations, means of egress, fire protection systems and interior finishes.

**SECTION 301  
GENERAL**

**301.1 Scope.** The provisions of this chapter shall control the classification of all buildings and structures as to use and occupancy.

❖ As used throughout the code, the classification of an occupancy into a group is established by the requirements of this chapter. The purpose of these provisions is to provide rational criteria for the classification of various occupancies into groups based on their relative fire hazard and life safety properties. This is necessary because the code utilizes group classification as a fundamental principle for differentiating requirements in other parts of the code related to fire and life safety protection.

**SECTION 302  
CLASSIFICATION**

**302.1 General.** Structures or portions of structures shall be classified with respect to occupancy in one or more of the groups listed in this section. A room or space that is intended to be occupied at different times for different purposes shall comply with all of the requirements that are applicable to each of the purposes for which the room or space will be occupied. Structures with multiple occupancies or uses shall comply with Section 508. Where a structure is proposed for a purpose that is not specifically provided for in this code, such structure shall be classified in the group that the occupancy most nearly resembles, according to the fire safety and relative hazard involved.

1. Assembly (see Section 303): Groups A-1, A-2, A-3, A-4 and A-5
2. Business (see Section 304): Group B
3. Educational (see Section 305): Group E
4. Factory and Industrial (see Section 306): Groups F-1 and F-2
5. High Hazard (see Section 307): Groups H-1, H-2, H-3, H-4 and H-5
6. Institutional (see Section 308): Groups I-1, I-2, I-3 and I-4
7. Mercantile (see Section 309): Group M
8. Residential (see Section 310): Groups R-1, R-2, R-3 and R-4
9. Storage (see Section 311): Groups S-1 and S-2
10. Utility and Miscellaneous (see Section 312): Group U

❖ This section requires all structures to be classified in one or more of the groups listed according to the structure's purpose and function (i.e., its occupancy). By organizing occupancies with similar fire hazard and life safety properties into groups, the code has incorporated the means to differentiate occupancies such that various fire protection and life safety requirements can be rationally organized and applied. Each specific group has an individual classi-

fication. Each represents a different characteristic and level of fire hazard that requires special code provisions to lessen the associated risks. There are some group classifications that are very closely related to other specific groups and, therefore, are collectively referred to as a single group (e.g., Group F applies to Groups F-1 and F-2). In these cases, there are requirements within the code that are common to each specific group classification. These common requirements are applicable based on the reference to the collective classification. For example, the automatic sprinkler system requirement of Section 903.2.8 applies to each specific group classification (R-1, R-2, R-3 and R-4) listed under the term "Group R." Although many requirements applicable to a general occupancy classification are the same for all of the subclassifications with the occupancy group, there are enough differences to warrant the division of the general category into two or more specific classifications.

**Example:** Both a restaurant (Group A-2) and a church (Group A-3) are included in Group A, but they have different specific group classifications. Both Groups A-2 and A-3 are subject to the same travel distance limitations (see Table 1016.1) and corridor fire-resistance ratings (see Table 1018.1), but have different thresholds for when automatic sprinkler systems are required (see Section 903).

Buildings that contain more than one occupancy group are mixed occupancy buildings. Buildings with mixed occupancies must comply with one of the design options contained in Section 508. Options established in Section 508 include the regulation of the mixed-occupancy conditions as accessory occupancies, nonseparated occupancies or separated occupancies.

Occasionally, a building or space is intended to be occupied for completely different purposes at different times. For instance, a church hall might be used as a day care center during weekdays and as a reception hall for weddings and other similar events at other times. In these cases, the code provisions for each occupancy must be satisfied.

In cases where a structure has a purpose that is not specifically identified within any particular occupancy classification, that structure is to be classified in the group that it most closely resembles. Before an accurate classification can be made, however, a detailed description of the activities or processes taking place inside the building, the occupant load and the materials and equipment used and stored therein must be submitted to the building official. The building official must then compare this information to the various occupancy classifications, determine which one the building most closely resembles and classify the building as such.

**Example:** A designer presents the building official with a building needing an occupancy group classification. The building official is informed that the building is to be used as an indoor shooting gallery, open

to the public but used mostly by police officers. After reviewing the code, the official cannot find a specific reference to a shooting gallery in Sections 303 through 312 or in the associated tables. The building official asks the designer for additional information about the activities to be conducted in the building and is told that there will be a small sign-in booth, patron waiting/viewing area and the actual shooting area. Based on this information, the building official can determine that the most logical classification of the building is Group A-3, assembly. This classification is based on the fact that the building is used for the congregation of people for recreation. A shooting gallery is similar in many respects to a bowling center, which is classified as Group A-3 (see Figure 302.1).

**SECTION 303  
ASSEMBLY GROUP A**

**303.1 Assembly Group A.** Assembly Group A occupancy includes, among others, the use of a building or structure, or a portion thereof, for the gathering of persons for purposes such as civic, social or religious functions; recreation, food or drink consumption or awaiting transportation.

❖ Because of the arrangement and density of the occupant load associated with occupancies classified in the Group A assembly category, the potential for multiple fatalities and injuries from fire is comparatively high. For example, no other use listed in Section 302.1 contemplates occupant loads as dense as 5 square feet (0.46 m<sup>2</sup>) per person (see Table 1004.1.1). Darkened spaces in theaters, nightclubs and the like serve to increase hazards. In sudden emergencies, the congestion caused by large numbers of people rushing to exits can cause panic conditions. For these and many other reasons, there is a relatively high degree of hazard to life safety in assembly facilities. The relative hazards of assembly occupancies are reflected in the height and area limitations of Table 503 that are, in comparison, gener-

ally more restrictive than for buildings in other group classifications.

There are five specific assembly group classifications, Groups A-1 through A-5, described in this section. Where used in the code, the general term “Group A” is intended to include all five classifications.

The fundamental characteristics of all assembly occupancies are identified in this section. Structures that are designed or occupied for assembly purposes must be placed in one of the assembly group classifications. There are buildings and spaces which are used for assembly purposes, but are not classified as Assembly occupancies. The “exceptions” to this rule include small assembly buildings, tenant spaces and assembly spaces in mixed-use buildings. These exceptions to the Group A classification are addressed in Sections 303.1.1 through 303.1.4.

**303.1.1 Small buildings and tenant spaces.** A building or tenant space used for assembly purposes with an *occupant load* of less than 50 persons shall be classified as a Group B occupancy.

❖ There are often small establishments that typically serve food and have a few seats that technically meet the definition of an assembly Group A occupancy but due to the low occupant load pose a lower risk than a typical assembly occupancy. These types of buildings and tenant spaces are to be considered as Group B occupancies when the occupant load is determined to be less than 50 persons. Examples of this include small “fast food” establishments and small “mom-and-pop” cafes or coffee shops.

**303.1.2 Small assembly spaces.** The following rooms and spaces shall not be classified as Assembly occupancies:

1. A room or space used for assembly purposes with an *occupant load* of less than 50 persons and accessory to another occupancy shall be classified as a Group B occupancy or as part of that occupancy.
2. A room or space used for assembly purposes that is less than 750 square feet (70 m<sup>2</sup>) in area and accessory to

