

PREFACE

Introduction

Internationally, code officials recognize the need for a modern, up-to-date mechanical code addressing the design and installation of mechanical systems through requirements emphasizing performance. The *International Mechanical Code*®, in this 2009 edition, is designed to meet these needs through model code regulations that safeguard the public health and safety in all communities, large and small.

This comprehensive mechanical code establishes minimum regulations for mechanical systems using prescriptive and performance-related provisions. It is founded on broad-based principles that make possible the use of new materials and new mechanical designs. This 2009 edition is fully compatible with all the *International Codes* (“I-Codes”) published by the International Code Council (ICC), including the *International Building Code*®, *International Energy Conservation Code*®, *International Existing Building Code*®, *International Fire Code*®, *International Fuel Gas Code*®, *International Plumbing Code*®, *ICC Performance Code*®, *International Private Sewage Disposal Code*®, *International Property Maintenance Code*®, *International Residential Code*®, *International Urban-Wildland Interface Code*™ and *International Zoning Code*®.

The *International Mechanical Code* provisions provide many benefits, among which is the model code development process that offers an international forum for mechanical professionals to discuss performance and prescriptive code requirements. This forum provides an excellent arena to debate proposed revisions. This model code also encourages international consistency in the application of provisions.

Development

The first edition of the *International Mechanical Code* (1996) was the culmination of an effort initiated in 1994 by a development committee appointed by the ICC and consisting of representatives of the three statutory members of the International Code Council at that time, including: Building Officials and Code Administrators International, Inc. (BOCA), International Conference of Building Officials (ICBO) and Southern Building Code Congress International (SBCCI). The intent was to draft a comprehensive set of regulations for mechanical systems consistent with and inclusive of the scope of the existing model codes. Technical content of the latest model codes promulgated by BOCA, ICBO and SBCCI was utilized as the basis for the development. This 2009 edition presents the code as originally issued, with changes approved through the ICC Code Development Process through 2008. A new edition such as this is promulgated every 3 years.

This code is founded on principles intended to establish provisions consistent with the scope of a mechanical code that adequately protects public health, safety and welfare; provisions that do not unnecessarily increase construction costs; provisions that do not restrict the use of new materials, products or methods of construction; and provisions that do not give preferential treatment to particular types or classes of materials, products or methods of construction.

Adoption

The *International Mechanical Code* is available for adoption and use by jurisdictions internationally. Its use within a governmental jurisdiction is intended to be accomplished through adoption by reference in accordance with proceedings establishing the jurisdiction’s laws. At the time of adoption, jurisdictions should insert the appropriate information in provisions requiring specific local information, such as the name of the adopting jurisdiction. These locations are shown in bracketed words in small capital letters in the code and in the sample ordinance. The sample adoption ordinance on page ix addresses several key elements of a code adoption ordinance, including the information required for insertion into the code text.

Maintenance

The *International Mechanical Code* is kept up to date through the review of proposed changes submitted by code enforcing officials, industry representatives, design professionals and other interested parties. Proposed changes are carefully considered through an open code development process in which all interested and affected parties may participate.

The contents of this work are subject to change both through the Code Development Cycles and the governmental body that enacts the code into law. For more information regarding the code development process, contact the Code and Standard Development Department of the International Code Council.

While the development procedure of the *International Mechanical Code* assures the highest degree of care, ICC and ICC’s members and those participating in the development of this code do not accept any liability resulting from compliance or noncompliance with the provisions because ICC and its members do not have the power or authority to police or enforce compliance with the contents of this code. Only the governmental body that enacts the code into law has such authority.

Letter Designations in Front of Section Numbers

In each code development cycle, proposed changes to this code are considered at the Code Development Hearing by the International Mechanical Code Development Committee, whose action constitutes a recommendation to the voting membership for final action on the proposed change. Proposed changes to a code section whose number begins with a letter in brackets are considered by a different code development committee. For instance, proposed changes to code sections which have the letter [B] in front (for example, [B] 309.1), are considered by one of the International Building Code development committees at the Code Development Hearing. Where this designation is applicable to the entire content of a main section of the code, the designation appears at the main section number and title and is not repeated at every subsection in that section.

The content of sections in this code which begin with a letter designation are maintained by another code development committee in accordance with the following:

- [B] = International Building Code Development Committee;
- [EC] = International Energy Conservation Code Development Committee;
- [F] = International Fire Code Development Committee; and
- [FG] = International Fuel Gas Code Development Committee.

Marginal Markings

Solid vertical lines in the margins within the body of the code indicate a technical change from the requirements of the 2006 edition. Deletion indicators (➤) are provided in the margin where an entire section, paragraph, exception or table has been deleted or an item in a list of items or in a table has been deleted.

Italicized Terms

Selected terms set forth in Chapter 2, Definitions, are italicized where they appear in code text. Such terms are not italicized where the definition set forth in Chapter 2 does not impart the intended meaning in the use of the term. The terms selected have definitions which the user should read carefully to facilitate better understanding of the code.

Effective Use of the International Mechanical Code

The *International Mechanical Code*® (IMC®) is a model code that regulates the design and installation of mechanical systems, appliances, appliance venting, duct and ventilation systems, combustion air provisions, hydronic systems and solar systems. The purpose of the code is to establish the minimum acceptable level of safety and to protect life and property from the potential dangers associated with the installation and operation of mechanical systems. The code also protects the personnel that install, maintain, service and replace the systems and appliances addressed by this code.

The IMC is primarily a prescriptive code with some performance text. The code relies heavily on product specifications and listings to provide much of the appliance and equipment installation requirements. The general Section 105.2 and the exception to Section 403.2 allow designs and installations to be performed by approved engineering methods as alternatives to the prescriptive methods in the code.

The format of the IMC allows each chapter to be devoted to a particular subject with the exception of Chapter 3, which contains general subject matters that are not extensive enough to warrant their own independent chapter.

Chapter 1 Scope and Administration. Chapter 1 establishes the limits of applicability of the code and describes how the code is to be applied and enforced. A mechanical code, like any other code, is intended to be adopted as a legally enforceable document and it cannot be effective without adequate provisions for its administration and enforcement. The provisions of Chapter 1 establish the authority and duties of the code official appointed by the jurisdiction having authority and also establish the rights and privileges of the design professional, contractor and property owner.

Chapter 2 Definitions. Chapter 2 is the repository of the definitions of terms used in the body of the code. Codes are technical documents and every word and term can impact the meaning of the code text and the intended results. The code often uses terms that have a unique meaning in the code and the code meaning can differ substantially from the ordinarily understood meaning of the term as used outside of the code.

The terms defined in Chapter 2 are deemed to be of prime importance in establishing the meaning and intent of the code text that uses the terms. The user of the code should be familiar with and consult this chapter because the definitions are essential to the correct interpretation of the code and because the user may not be aware that a term is defined.

Chapter 3 General Regulations. Chapter 3 contains broadly applicable requirements related to appliance location and installation, appliance and systems access, protection of structural elements, condensate disposal and clearances to combustibles, among others.

Chapter 4 Ventilation. Chapter 4 includes means for protecting building occupant health by controlling the quality of indoor air and protecting property from the effects of inadequate ventilation. In some cases, ventilation is required to prevent or reduce a health hazard by removing contaminants at their source.

Ventilation is both necessary and desirable for the control of air contaminants, moisture and temperature. Habitable and occupiable spaces are ventilated to promote a healthy and comfortable environment for the occupants. Uninhabited and unoccupied spaces are ventilated to protect the building structure from the harmful effects of excessive humidity and heat. Ventilation of specific occupancies is necessary to minimize the potential for toxic or otherwise harmful substances to reach dangerously high concentrations in air.

Chapter 5 Exhaust Systems. Chapter 5 provides guidelines for reasonable protection of life, property and health from the hazards associated with exhaust systems, air contaminants and smoke development in the event of a fire. In most cases, these hazards involve materials and gases that are flammable, explosive, toxic or otherwise hazardous. Where contaminants are known to be present in quantities that are irritating or harmful to the occupants' health or are hazardous in a fire, both naturally and mechanically ventilated spaces must be equipped with mechanical exhaust systems capable of collecting and removing the contaminants.

This chapter contains requirements for the installation of exhaust systems, with an emphasis on the structural integrity of the systems and equipment involved and the overall impact of the systems on the fire safety performance of the building. It includes requirements for the exhaust of commercial kitchen grease- and smoke-laden air, hazardous fumes and toxic gases, clothes dryer moisture and heat and dust, stock and refuse materials.

Chapter 6 Duct Systems. Chapter 6 of the code regulates the materials and methods used for constructing and installing ducts, plenums, system controls, exhaust systems, fire protection systems and related components that affect the overall performance of a building's air distribution system and the reasonable protection of life and property from the hazards associated with air-moving equipment and systems. This chapter contains requirements for the installation of supply, return and exhaust air systems. Specific exhaust systems are also addressed in Chapter 5. Information on the design of duct systems is limited to that in Section 603.2. The code is very much concerned with the structural integrity of the systems and the overall impact of the systems on the fire safety and life safety performance of the building. Design considerations such as duct sizing, maximum efficiency, cost effectiveness, occu-

pant comfort and convenience are the responsibility of the design professional. The provisions for the protection of duct penetrations of wall, floor, ceiling and roof assemblies are extracted from the *International Building Code*.

Chapter 7 Combustion Air. Complete combustion of solid and liquid fuel is essential for the proper operation of appliances, for control of harmful emissions and for achieving maximum fuel efficiency.

The specific combustion air requirements provided in previous editions of the code have been deleted in favor of a single section that directs the user to NFPA 31 for oil-fired appliance combustion air requirements and the manufacturer's installation instructions for solid-fuel burning appliances. For gas-fired appliances, the provisions of the *International Fuel Gas Code* are applicable.

Chapter 8 Chimneys and Vents. Chapter 8 is intended to regulate the design, construction, installation, maintenance, repair and approval of chimneys, vents and their connections to solid and liquid fuel-burning appliances. The requirements of this chapter are intended to achieve the complete removal of the products of combustion from fuel-burning appliances and equipment. This chapter includes regulations for the proper selection, design, construction and installation of a chimney or vent, along with appropriate measures to minimize the related potential fire hazards. A chimney or vent must be designed for the type of appliance or equipment it serves. Chimneys and vents are designed for specific applications depending on the flue gas temperatures and the type of fuel being burned in the appliance. Chimneys and vents for gas-fired appliances are covered in the *International Fuel Gas Code*.

Chapter 9 Specific Appliances, Fireplaces and Solid Fuel-burning Appliances. Chapter 9 sets minimum construction and performance criteria for fireplaces, appliances and equipment and provides for the safe installation of these items. It reflects the code's intent to specifically address all of the types of appliances that the code intends to regulate. Other regulations affecting the installation of solid fuel-burning fireplaces, appliances and accessory appliances are found in Chapters 3, 6, 7, 8, 10, 11, 12, 13 and 14.

Chapter 10 Boilers, Water Heaters and Pressure Vessels. Chapter 10 presents regulations for the proper installation of boilers, water heaters and pressure vessels to protect life and property from the hazards associated with those appliances and vessels. It applies to all types of boilers and pressure vessels, regardless of size, heat input, operating pressure or operating temperature.

Because pressure vessels are closed containers designed to contain liquids, gases or both under pressure, they must be designed and installed to prevent structural failures that can result in extremely hazardous situations. Certain safety features are therefore provided in Chapter 10 to reduce the potential for explosion hazards.

Chapter 11 Refrigeration. Chapter 11 contains regulations pertaining to the life safety of building occupants. These regulations establish minimum requirements to achieve the proper design, construction, installation and operation of refrigeration systems. Refrigeration systems are a combination of interconnected components and piping assembled to form a closed circuit in which a refrigerant is circulated. The system's function is to extract heat from a location or medium, and to reject that heat to a different location or medium. This chapter establishes reasonable safeguards for the occupants by defining and mandating practices that are consistent with the practices and experience of the industry.

Chapter 12 Hydronic Piping. Hydronic piping includes piping, fittings and valves used in building space conditioning systems. Applications include hot water, chilled water, steam, steam condensate, brines and water/antifreeze mixtures. Chapter 12 contains the provisions that govern the construction, installation, alteration and repair of all hydronic piping systems that affect reliability, serviceability, energy efficiency and safety.

Chapter 13 Fuel Oil Piping and Storage. Chapter 13 regulates the design and installation of fuel oil storage and piping systems. The regulations include reference to construction standards for above-ground and underground storage tanks, material standards for piping systems (both above-ground and underground) and extensive requirements for the proper assembly of system piping and components. The *International Fire Code*® (IFC®) covers subjects not addressed in detail here. The provisions in this chapter are intended to prevent fires, leaks and spills involving fuel oil storage and piping systems.

Chapter 14 Solar Systems. Chapter 14 establishes provisions for the safe installation, operation and repair of solar energy systems used for space heating or cooling, domestic hot water heating or processing. Although such systems use components similar to those of conventional mechanical equipment, many of these provisions are unique to solar energy systems.

Chapter 15 Referenced Standards. Chapter 15 lists all of the product and installation standards and codes that are referenced throughout Chapters 1 through 14. As stated in Section 102.8, these standards and codes become an enforceable part of the code (to the prescribed extent of the reference) as if printed in the body of the code. Chapter 15 provides the full title and edition year of the standards and codes in addition to the address of the promulgators and the section numbers in which the standards and codes are referenced.

Appendix A Combustion Air Openings and Chimney Connector Pass-throughs. Appendix A provides figures that illustrate various requirements in the body of the code. Figures A-1 through A-4 illustrate typical combustion air requirements. Figure A-5 illustrates the chimney connector clearance requirements of Table 803.10.4.

Appendix B Recommended Permit Fee Schedule. Appendix B provides a sample permit fee schedule for mechanical permits. The local jurisdiction can adopt this appendix and fill in the dollar amounts in the blank spaces to establish their official permit fee schedule. The ICC does not establish permit fees because the code is adopted throughout the country and there are vast differences in operating budgets between different parts of the country, as well as between large and small municipalities within the same region.

ORDINANCE

The *International Codes* are designed and promulgated to be adopted by reference by ordinance. Jurisdictions wishing to adopt the 2009 *International Mechanical Code* as an enforceable regulation governing plumbing systems should ensure that certain factual information is included in the adopting ordinance at the time adoption is being considered by the appropriate governmental body. The following sample adoption ordinance addresses several key elements of a code adoption ordinance, including the information required for insertion into the code text.

SAMPLE ORDINANCE FOR ADOPTION OF THE INTERNATIONAL MECHANICAL CODE ORDINANCE NO. _____

An ordinance of the [JURISDICTION] adopting the 2009 edition of the *International Mechanical Code*, regulating and governing the design, construction, quality of materials, erection, installation, alteration, repair, location, relocation, replacement, addition to, use or maintenance of mechanical systems in the [JURISDICTION]; providing for the issuance of permits and collection of fees therefor; repealing Ordinance No. _____ of the [JURISDICTION] and all other ordinances and parts of the ordinances in conflict therewith.

The [GOVERNING BODY] of the [JURISDICTION] does ordain as follows:

Section 1. That a certain document, three (3) copies of which are on file in the office of the [TITLE OF JURISDICTION'S KEEPER OF RECORDS] of [NAME OF JURISDICTION], being marked and designated as the *International Mechanical Code*, 2009 edition, including Appendix Chapters [FILL IN THE APPENDIX CHAPTERS BEING ADOPTED], as published by the International Code Council, be and is hereby adopted as the Mechanical Code of the [JURISDICTION], in the State of [STATE NAME] regulating and governing the design, construction, quality of materials, erection, installation, alteration, repair, location, relocation, replacement, addition to, use or maintenance of plumbing systems as herein provided; providing for the issuance of permits and collection of fees therefor; and each and all of the regulations, provisions, penalties, conditions and terms of said Mechanical Code on file in the office of the [JURISDICTION] are hereby referred to, adopted, and made a part hereof, as if fully set out in this ordinance, with the additions, insertions, deletions and changes, if any, prescribed in Section 2 of this ordinance.

Section 2. The following sections are hereby revised:

Section 101.1. Insert: [NAME OF JURISDICTION]

Section 106.5.2. Insert: [APPROPRIATE SCHEDULE]

Section 106.5.3. Insert: [PERCENTAGES IN TWO LOCATIONS]

Section 108.4. Insert: [OFFENSE, DOLLAR AMOUNT, NUMBER OF DAYS]

Section 108.5. Insert: [DOLLAR AMOUNT IN TWO LOCATIONS]

Section 3. That Ordinance No. _____ of [JURISDICTION] entitled [FILL IN HERE THE COMPLETE TITLE OF THE ORDINANCE OR ORDINANCES IN EFFECT AT THE PRESENT TIME SO THAT THEY WILL BE REPEALED BY DEFINITE MENTION] and all other ordinances or parts of ordinances in conflict herewith are hereby repealed.

Section 4. That if any section, subsection, sentence, clause or phrase of this ordinance is, for any reason, held to be unconstitutional, such decision shall not affect the validity of the remaining portions of this ordinance. The [GOVERNING BODY] hereby declares that it would have passed this ordinance, and each section, subsection, clause or phrase thereof, irrespective of the fact that any one or more sections, subsections, sentences, clauses and phrases be declared unconstitutional.

Section 5. That nothing in this ordinance or in the Mechanical Code hereby adopted shall be construed to affect any suit or proceeding impending in any court, or any rights acquired, or liability incurred, or any cause or causes of action acquired or existing, under any act or ordinance hereby repealed as cited in Section 2 of this ordinance; nor shall any just or legal right or remedy of any character be lost, impaired or affected by this ordinance.

Section 6. That the [JURISDICTION'S KEEPER OF RECORDS] is hereby ordered and directed to cause this ordinance to be published. (An additional provision may be required to direct the number of times the ordinance is to be published and to specify that it is to be in a newspaper in general circulation. Posting may also be required.)

Section 7. That this ordinance and the rules, regulations, provisions, requirements, orders and matters established and adopted hereby shall take effect and be in full force and effect [TIME PERIOD] from and after the date of its final passage and adoption.

TABLE OF CONTENTS

<p>CHAPTER 1 SCOPE AND ADMINISTRATION . . . 1</p> <p>PART 1—SCOPE AND APPLICATION 1</p> <p>Section</p> <p>101 General 1</p> <p>102 Applicability 1</p> <p>PART 2—ADMINISTRATION AND ENFORCEMENT 2</p> <p>103 Department of Mechanical Inspection 2</p> <p>104 Duties and Powers of the Code Official 2</p> <p>105 Approval 2</p> <p>106 Permits 3</p> <p>107 Inspections and Testing 5</p> <p>108 Violations 6</p> <p>109 Means of Appeal 7</p> <p>110 Temporary Equipment, Systems and Uses 8</p> <p>CHAPTER 2 DEFINITIONS 9</p> <p>Section</p> <p>201 General 9</p> <p>202 General Definitions 9</p> <p>CHAPTER 3 GENERAL REGULATIONS 19</p> <p>Section</p> <p>301 General 19</p> <p>302 Protection of Structure 20</p> <p>303 Equipment and Appliance Location 21</p> <p>304 Installation 21</p> <p>305 Piping Support 22</p> <p>306 Access and Service Space 23</p> <p>307 Condensate Disposal 24</p> <p>308 Clearance Reduction 25</p> <p>309 Temperature Control 27</p> <p>310 Explosion Control 27</p> <p>311 Smoke and Heat Vents 27</p> <p>312 Heating and Cooling Load Calculations 27</p> <p>CHAPTER 4 VENTILATION 29</p> <p>Section</p> <p>401 General 29</p> <p>402 Natural Ventilation 29</p> <p>403 Mechanical Ventilation 30</p>	<p>404 Enclosed Parking Garages 35</p> <p>405 Systems Control 35</p> <p>406 Ventilation of Uninhabited Spaces 35</p> <p>CHAPTER 5 EXHAUST SYSTEMS 37</p> <p>Section</p> <p>501 General 37</p> <p>502 Required Systems 37</p> <p>503 Motors and Fans 44</p> <p>504 Clothes Dryer Exhaust 44</p> <p>505 Domestic Kitchen Exhaust Equipment 46</p> <p>506 Commercial Kitchen Hood Ventilation System Ducts and Exhaust Equipment 46</p> <p>507 Commercial Kitchen Hoods 50</p> <p>508 Commercial Kitchen Makeup Air 52</p> <p>509 Fire Suppression Systems 52</p> <p>510 Hazardous Exhaust Systems 52</p> <p>511 Dust, Stock and Refuse Conveying Systems 54</p> <p>512 Subslab Soil Exhaust Systems 55</p> <p>513 Smoke Control Systems 56</p> <p>514 Energy Recovery Ventilation Systems 59</p> <p>CHAPTER 6 DUCT SYSTEMS 61</p> <p>Section</p> <p>601 General 61</p> <p>602 Plenums 61</p> <p>603 Duct Construction and Installation 63</p> <p>604 Insulation 64</p> <p>605 Air Filters 65</p> <p>606 Smoke Detection Systems Control 65</p> <p>607 Duct and Transfer Openings 66</p> <p>CHAPTER 7 COMBUSTION AIR 71</p> <p>Section</p> <p>701 General 71</p> <p>CHAPTER 8 CHIMNEYS AND VENTS 73</p> <p>Section</p> <p>801 General 73</p> <p>802 Vents 74</p> <p>803 Connectors 75</p> <p>804 Direct-vent, Integral Vent and Mechanical Draft Systems 76</p>
--	--

TABLE OF CONTENTS

805 Factory-built Chimneys 77
 806 Metal Chimneys 78

**CHAPTER 9 SPECIFIC APPLIANCES,
 FIREPLACES AND SOLID FUEL-
 BURNING EQUIPMENT 79**

Section

901 General 79
 902 Masonry Fireplaces 79
 903 Factory-built Fireplaces 79
 904 Pellet Fuel-burning Appliances 79
 905 Fireplace Stoves and Room Heaters 79
 906 Factory-built Barbecue Appliances 79
 907 Incinerators and Crematories 79
 908 Cooling Towers, Evaporative
 Condensers and Fluid Coolers 79
 909 Vented Wall Furnaces 80
 910 Floor Furnaces 80
 911 Duct Furnaces 80
 912 Infrared Radiant Heaters 80
 913 Clothes Dryers 80
 914 Sauna Heaters 81
 915 Engine and Gas Turbine-powered
 Equipment and Appliances 81
 916 Pool and Spa Heaters 81
 917 Cooking Appliances 81
 918 Forced-air, Warm-air Furnaces 81
 919 Conversion Burners 82
 920 Unit Heaters 82
 921 Vented Room Heaters 83
 922 Kerosene and Oil-fired Stoves 83
 923 Small Ceramic Kilns 83
 924 Stationary Fuel Cell Power Systems 83
 925 Masonry Heaters 83
 926 Gaseous Hydrogen Systems 83
 927 Heat Recovery Ventilators 83

**CHAPTER 10 BOILERS, WATER HEATERS
 AND PRESSURE VESSELS 85**

Section

1001 General 85
 1002 Water Heaters 85
 1003 Pressure Vessels 85
 1004 Boilers 85
 1005 Boiler Connections 86

1006 Safety and Pressure Relief Valves
 and Controls 86
 1007 Boiler Low-water Cutoff 86
 1008 Steam Blowoff Valve 87
 1009 Hot Water Boiler Expansion Tank 87
 1010 Gauges 87
 1011 Tests 87

CHAPTER 11 REFRIGERATION 89

Section

1101 General 89
 1102 System Requirements 89
 1103 Refrigeration System Classification 90
 1104 System Application Requirements 90
 1105 Machinery Room, General Requirements 96
 1106 Machinery Room, Special Requirements 97
 1107 Refrigerant Piping 97
 1108 Field Test 99
 1109 Periodic Testing 99

CHAPTER 12 HYDRONIC PIPING 101

Section

1201 General 101
 1202 Material 101
 1203 Joints and Connections 102
 1204 Pipe Insulation 103
 1205 Valves 104
 1206 Piping Installation 104
 1207 Transfer Fluid 104
 1208 Tests 104
 1209 Embedded Piping 105

**CHAPTER 13 FUEL OIL PIPING
 AND STORAGE 107**

Section

1301 General 107
 1302 Material 107
 1303 Joints and Connections 107
 1304 Piping Support 108
 1305 Fuel Oil System Installation 108
 1306 Oil Gauging 109
 1307 Fuel Oil Valves 109
 1308 Testing 109

CHAPTER 14 SOLAR SYSTEMS..... 111
 Section
 1401 General..... 111
 1402 Installation..... 111
 1403 Heat Transfer Fluids 112
 1404 Materials..... 112

CHAPTER 15 REFERENCED STANDARDS..... 113

**APPENDIX A COMBUSTION AIR OPENINGS AND
 CHIMNEY CONNECTOR
 PASS-THROUGHS 121**

**APPENDIX B RECOMMENDED PERMIT
 FEE SCHEDULE 125**

INDEX..... 127

CHAPTER 15

REFERENCED STANDARDS

This chapter lists the standards that are referenced in various sections of this document. The standards are listed herein by the promulgating agency of the standard, the standard identification, the effective date and title, and the section or sections of this document that reference the standard. The application of the referenced standards shall be as specified in Section 102.8.

ACCA	Air Conditioning Contractors of America 2800 Shirlington Road, Suite 300 Arlington, VA 22206	Referenced in code section number
Standard Reference Number	Title	
Manual D—95	Residential Duct Systems603.2
183—2007	Peak Cooling and Heating Load Calculations in Buildings Except Low-Rise Residential Buildings.312.1

AHRI	Air-Conditioning, Heating and Refrigeration Institute 4100 North Fairfax Drive, Suite 200 Arlington, VA 22203	Referenced in code section number
Standard Reference Number	Title	
700—99	Purity Specifications for Fluorocarbon and Other Refrigerants1102.2.2.3

ANSI	American National Standards Institute 11 West 42nd Street New York, NY 10036	Referenced in code section number
Standard Reference Number	Title	
Z21.8—1994 (R2002)	Installation of Domestic Gas Conversion Burners919.1

ASHRAE	American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. 1791 Tullie Circle, NE Atlanta, GA 30329	Referenced in code section number
Standard Reference Number	Title	
ASHRAE—2005	ASHRAE Fundamentals Handbook—2005603.2
15—2004	Safety Standard for Refrigeration Systems1101.6, 1108.1
34—2004	Designation and Safety Classification of Refrigerants202, 1102.2.1, 1103.1
62.1—2004	Ventilation for Acceptable Indoor Air Quality.403.3.2.3.2

ASME	American Society of Mechanical Engineers Three Park Avenue New York, NY 10016-5990	Referenced in code section number
Standard Reference Number	Title	
B1.20.1—1983 (R2006)	Pipe Threads, General Purpose (Inch)1203.3.5, 1303.3.3
B16.3—2006	Malleable Iron Threaded Fittings, Classes 150 & 300Table 1202.5
B16.5—2003	Pipe Flanges and Flanged Fittings NPS 1/2 through NPS 24—Table 1202.5
B16.9—2003	Factory Made Wrought Steel Butt-welding FittingsTable 1202.5
B16.11—2005	Forged Fittings, Socket-welding and Threaded.Table 1202.5
B16.15—2006	Cast Bronze Threaded FittingsTable 1202.5

REFERENCED STANDARDS

ASME—continued

B16.18—2001 (Reaffirmed 2005)	Cast Copper Alloy Solder Joint Pressure Fittings	513.13.1, Table 1202.5
B16.22—2001 (Reaffirmed 2005)	Wrought Copper and Copper Alloy Solder Joint Pressure Fittings	513.13.1, Table 1202.5
B16.23—2002 (Reaffirmed 2006)	Cast Copper Alloy Solder Joint Drainage Fittings DWV	Table 1202.5
B16.24—2001	Cast Copper Alloy Pipe Flanges and Flanged Fittings: Class 150, 300, 400, 600, 900, 1500 and 2500	Table 1202.5
B16.26—2006	Cast Copper Alloy Fittings for Flared Copper Tubes	Table 1202.5
B16.28—1994	Wrought Steel Butt welding Short Radius Elbows and Returns	Table 1202.5
B16.29—2001	Wrought Copper and Wrought Copper Alloy Solder Joint Drainage Fittings-DWV	Table 1202.5
B31.9—04	Building Services Piping	1201.3
BPVC—2004	Boiler & Pressure Vessel Code	1004.1, 1011.1
CSD-1—2004	Controls and Safety Devices for Automatically Fired Boilers	1004.1

ASSE

American Society of Sanitary Engineering
901 Canterbury, Suite A
Westlake, OH 44145

Standard Reference Number	Title	Referenced in code section number
1017—03	Performance Requirements for Temperature Actuated Mixing Values for Hot Water Distribution Systems	1002.2.2

ASTM

ASTM International
100 Barr Harbor Drive
West Conshohocken, PA 19428

Standard Reference Number	Title	Referenced in code section number
A 53/A 53M—06a	Specification for Pipe, Steel, Black and Hot-dipped, Zinc-coated Welded and Seamless	Table 1202.4, Table 1302.3
A 106/A106M—06a	Specification for Seamless Carbon Steel Pipe for High-Temperature Service	Table 1202.4, Table 1302.3
A 126—04	Specification for Gray Iron Castings for Valves, Flanges and Pipe Fittings	Table 1202.5
A 254—97 (2002)	Specification for Copper Brazed Steel Tubing	Table 1202.4, Table 1302.3
A 420/A 420M—07	Specification for Piping Fittings of Wrought Carbon Steel and Alloy Steel for Low-Temperature Service	Table 1202.5
A 539—99	Specification for Electric-Resistance-Welded Coiled Steel Tubing for Gas and Fuel Oil Lines	Table 1302.3
B 32—04	Specification for Solder Metal	1203.3.3
B 42—02e01	Specification for Seamless Copper Pipe, Standard Sizes	513.13.1, 1107.5.2, Table 1202.4, Table 1302.3
B 43—98(2004)	Specification for Seamless Red Brass Pipe, Standard Sizes	513.13.1, 1107.5.2, Table 1202.4, Table 1302.3
B 68—02	Specification for Seamless Copper Tube, Bright Annealed	513.13.1
B 75—02	Specification for Seamless Copper Tube	Table 1202.4, Table 1302.3
B 88—03	Specification for Seamless Copper Water Tube	513.13.1, 1107.5.3, Table 1202.4, Table 1302.3
B 135—02	Specification for Seamless Brass Tube	Table 1202.4, Table 1302.3
B 251—02e01	Specification for General Requirements for Wrought Seamless Copper and Copper-alloy Tube	513.13.1, Table 1202.4
B 280—03	Specification for Seamless Copper Tube for Air Conditioning and Refrigeration Field Service	513.13.1, 1107.4.3, Table 1302.3
B 302—02	Specification for Threadless Copper Pipe, Standard Sizes	Table 1202.4, Table 1302.3
B 813—00e01	Specification for Liquid and Paste Fluxes for Soldering of Copper and Copper Alloy Tube	1203.3.3
C 315—07	Specification for Clay Flue Liners and Chimney Pots	801.16.1, Table 803.10.4
C 411—05	Test Method for Hot-surface Performance of High-temperature Thermal Insulation	604.3
D 56—05	Test Method for Flash Point by Tag Closed Tester	202
D 93—07	Test Method for Flash Point of Pensky-Martens Closed Cup Tester	202
D 1527—99(2005)	Specification for Acrylonitrile-Butadiene-Styrene (ABS) Plastic Pipe, Schedules 40 and 80	Table 1202.4
D 1693—07	Test Method for Environmental Stress-Cracking of Ethylene Plastics	Table 1202.4
D 1785—06	Specification for Poly (Vinyl Chloride)(PVC) Plastic Pipe, Schedules 40, 80 and 120	Table 1202.4
D 2235—04	Specifications for Solvent Cement for Acrylonitrile-Butadiene-Styrene (ABS) Plastic Pipe and Fittings	1203.3.4
D 2241—05	Specification for Poly (Vinyl Chloride)(PVC) Pressure-rated Pipe (SDR-Series)	Table 1202.4
D 2282—99(2005)	Specification for Acrylonitrile-Butadiene-Styrene (ABS) Plastic Pipe (SDR-PR)	Table 1202.4
D 2412—02	Test Method for Determination of External Loading Characteristics of Plastic Pipe by Parallel-plate Loading	603.8.3
D 2447—03	Specification for Polyethylene (PE) Plastic Pipe, Schedules 40 and 80, Based on Outside Diameter	Table 1202.4

ASTM—continued

D 2466—06	Specification for Poly (Vinyl Chloride)(PVC) Plastic Pipe Fittings, Schedule 40.	Table 1202.5
D 2467—06	Specification for Poly (Vinyl Chloride)(PVC) Plastic Pipe Fittings, Schedule 80.	Table 1202.5
D 2468—96a	Specification for Acrylonitrile-Butadiene-Styrene (ABS) Plastic Pipe Fittings, Schedule 40.	Table 1202.5
D 2513—07a	Specification for Thermoplastic Gas Pressure Pipe, Tubing, and Fittings	Table 1202.4
D 2564—04e01	Specification for Solvent Cements for Poly (Vinyl Chloride) (PVC) Plastic Piping Systems	1203.3.4
D 2657—07	Standard Practice for Heat Fusion Joining of Polyolefin Pipe and Fittings.	1203.15.1
D 2683—04	Specification for Socket-type Polyethylene Fittings for Outside Diameter-controlled Polyethylene Pipe and Tubing.	Table 1202.4, 1203.15.1
D 2837—04e01	Test Method for Obtaining Hydrostatic Design Basis for Thermoplastic Pipe Materials or Pressure Design Basis for Thermoplastic Pipe Products	Table 1202.4
D 2846/D 2846M—06	Specification for Chlorinated Poly (Vinyl Chloride) (CPVC) Plastic Hot and Cold Water Distribution Systems	Table 1202.4, 1203.3.4
D 2996—01(2007)e01	Specification for Filament-wound Fiberglass (Glass Fiber Reinforced Thermosetting Resin) Pipe	Table 1302.3
D 3035—06	Specification for Polyethylene (PE) Plastic Pipe (DR-PR) Based on Controlled Outside Diameter.	Table 1202.4
D 3278—96(2004)e01	Test Methods for Flash Point of Liquids by Small Scale Closed-cup Apparatus	202
D 3261—03	Standard Specification for Butt Heat Fusion Polyethylene (PE) Plastic Fittings for Polyethylene (PE) Plastic Pipe and Tubing	1203.15.1
D 3309—96a(2002)	Specification for Polybutylene (PB) Plastic Hot and Cold Water Distribution Systems	Table 1202.4, 1203.10.1
D 3350—06	Specification for Polyethylene Plastics Pipe and Fittings Materials.	Table 1202.4
E 84—07	Test Method for Surface Burning Characteristics of Building Materials	202, 510.8, 602.2.1, 602.2.1.5, 604.3, 1204.1
E 119—07	Test Method for Fire Tests of Building Construction and Materials	607.5.2, 607.5.5, 607.6.1, 607.2.1
E 136—04	Test Method for Behavior of Materials in a Vertical Tube Furnace at 750 Degrees C	202
E 814—06	Test Method for Fire Tests of Through-penetration Fire Stops	506.3.10.2, 506.3.10.3
E 1509—04	Specification for Room Heaters, Pellet Fuel-burning Type	904.1
E 2231—04	Standard Practice For Specimen Preparation and Mounting of Pipe and Duct Insulation Materials to Assess Surface Burning Characteristics.	604.3, 1204.1
E 2336-04	Standard Test Methods for Fire Resistive Grease Duct Enclosure Systems.	506.3.6, 506.3.10.2
F 438—04	Specification for Socket Type Chlorinated Poly (Vinyl Chloride) (CPVC) Plastic Pipe Fittings, Schedule 40.	Table 1202.5
F 439—06	Specification for Socket Type Chlorinated Poly (Vinyl Chloride) (CPVC) Plastic Pipe Fittings, Schedule 80.	Table 1202.5
F 441/F 441M—02	Specification for Chlorinated Poly (Vinyl Chloride) (CPVC) Plastic Pipe, Schedules 40 and 80	Table 1202.4
F 442/F 442M—99(2005)	Specification for Chlorinated Poly (Vinyl Chloride) (CPVC) Plastic Pipe (SDR-PR).	Table 1202.4
F 493—04	Specification for Solvent Cements for Chlorinated Poly (Vinyl Chloride) (CPVC) Plastic Pipe and Fittings	1203.3.4
F 876—06	Specification for Crosslinked Polyethylene (PEX) Tubing.	Table 1202.4
F 877—07	Specification for Crosslinked Polyethylene (PEX) Plastic Hot and Cold Water Distribution Systems	Table 1202.4, Table 1202.5
F 1055—98(2006)	Specification for Electrofusion Type Polyethylene Fittings for Outside Diameter Controlled Polyethylene Pipe and Fittings	Table 1202.4, 1203.15.2
F 1281—07	Specification for Crosslinked Polyethylene/Aluminum/Crosslinked Polyethylene (PEX-AL-PEX) Pressure Pipe	Table 1202.4
F 1282—06	Standard Specification for Polyethylene/Aluminum/Polyethylene (PE-AL-PE) Composite Pressure Pipe	Table 1202.4
F 1476—(2006)	Specification for Performance of Gasketed Mechanical Couplings for Use in Piping Applications	1203.3.7
F 1924—05	Standard Specification for Plastic Mechanical Fittings for Use on Outside Diameter Controlled Polyethylene Gas Distribution Pipe and Tubing	1203.15.3
F 1974—04	Standard Specification for Metal Insert Fittings for Polyethylene/Aluminum/Polyethylene and Crosslinked Polyethylene/Aluminum/Crosslinked Polyethylene Composite Pressure Pipe	Table 1202.5
F 2389—06	Specification for Pressure-Rated Polypropylene Piping Systems	Table 1202.4, Table 1202.5
F 2623—07	Standard Specification for Polyethylene of Raised Temperature (PE-RT) SDR 9 Tubing1.	Table 1202.4

American Welding Society
 550 N.W. LeJeune Road
 P.O. Box 351040
 Miami, FL 33135



Standard Reference Number	Title	Referenced in code section number
A5.8—2004	Specifications for Filler Metals for Brazing and Braze Welding.	1203.3.1, 1303.3.1

REFERENCED STANDARDS

AWWA

American Water Work Association
6666 West Quincy Avenue
Denver, CO 80235

Standard Reference Number	Title	Referenced in code section number
C110/A21.10—03	Standard for Ductile Iron & Gray Iron Fittings, 2 inches Through 48 inches for Water	Table 1202.5
C115/A21.15—99	Standard for Flanged Ductile-iron Pipe with Ductile Iron or Grey-iron Threaded Flanges	Table 1202.4
C151/A21.51—02	Standard for Ductile-Iron Pipe, Centrifugally Cast for Water	Table 1202.4
C153/A21.53—00	Standard for Ductile-Iron Compact Fittings for Water Service	Table 1202.5

CSA

Canadian Standards Association
5060 Spectrum Way
Mississauga, Ontario, Canada L4W 5N6

Standard Reference Number	Title	Referenced in code section number
B137.9-M91 CAN/CSA	Polyethylene/Aluminum/Polyethylene (PE-AL-PE) Composite Pressure-Pipe Systems.	Table 1202.4
B137.10—02	Cross-linked Polyethylene/Aluminum/Cross-linked Polyethylene Composite Pressure-Pipe Systems.	Table 1202.4
ANSI CSA America FC1-03	Stationary Fuel Cell Power Systems924.1

DOL

Department of Labor
Occupational Safety and Health Administration
c/o Superintendent of Documents
US Government Printing Office
Washington, DC 20402-9325

Standard Reference Number	Title	Referenced in code section number
29 CFR Part 1910.1000 (1974)	Air Contaminants502.6
29 CFR Part 1910. 1025	Toxic and Hazardous Substances502.19

FS

Federal Specifications*
General Services Administration
7th & D Streets
Specification Section, Room 6039
Washington, DC 20407

Standard Reference Number	Title	Referenced in code section number
WW-P-325B (1976)	Pipe, Bends, Traps, Caps and Plugs; Lead (for Industrial Pressure and Soil and Waste Applications.	Table 1202.4

*Standards are available from the Supt. of Documents, U.S. Government Printing Office, Washington, DC 20402-9325.

ICC

International Code Council, Inc.
500 New Jersey Ave, NW
6th Floor
Washington, DC 20001

Standard Reference Number	Title	Referenced in code section number
IBC—09	International Building Code®201.3, 202, 301.12, 301.14, 301.15, 302.1, 302.2, 304.7, 304.10, 308.8, 308.10, 401.4, 401.6, 406.1, 502.10, 502.10.1, 504.2, 506.3.3, 506.3.10, 506.3.12.2, 506.4.1, 509.1, 510.6, 510.6.3, 510.6.2, 510.7, 511.1.5, 513.1, 513.2, 513.3, 513.4.3, 513.5, 513.5.2, 513.5.2.1, 513.6.2, 513.10.5, 513.12, 513.12.2, 513.20, 602.2.1.5.1, 602.2.1.5.2, 602.3, 603.1, 603.10, 604.5.4, 607.1.1, 607.3.2.1, 607.5.1, 607.5.2, 607.5.3, 607.5.4, 607.5.4.1, 607.5.5, 607.5.5.1, 607.6, 607.6.2, 701.4.1, 701.4.2, 801.3, 801.16.1, 801.18.4, 902.1, 908.3, 908.4, 910.3, 925.1, 1004.6, 1105.1, 1206.4, 1402.4, 1402.4.1
IEBC—09	International Existing Building Code®101.2
IECC—09	International Energy Conservation Code®202, 301.2, 303.3, 312.1, 603.9, 604.1, 1204.1, 1204.2

ICC—continued

IFC—09	International Fire Code®	201.3, 310.1, 311.1, 502.4, 502.5, 502.7.2, 502.8.1, 502.9.5, 502.9.5.2, 502.9.5.3, 502.9.8.2, 502.9.8.3, 502.9.8.5, 502.9.8.6, 502.10, 502.10.3, 502.16.2, 509.1, 510.2.1, 510.2.2, 510.4, 511.1.1 513.12.3, 513.15, 513.16, 513.17, 513.18, 513.19, 513.20.2, 513.20.3, 606.2.1, 908.7, 1101.9, 1105.3, 1106.5, 1106.6, 1301.1, 1301.2
IFGC—09	International Fuel Gas Code®	101.2, 201.3, 301.3, 701.1, 801.1, 901.1, 906.1, 1101.5
IPC—09	International Plumbing Code®	201.3, 301.8, 512.2, 908.5, 1002.1, 1002.2, 1002.3, 1005.2, 1006.6, 1008.2, 1009.3, 1101.4, 1201.1, 1206.2, 1206.3, 1401.2
IRC—09	International Residential Code®	101.2

IIAR

International Institute of Ammonia Refrigeration
1110 North Glebe Road
Arlington, VA 22201

Standard Reference Number	Title	Referenced in code section number
2—99 (with Addendum A-2005)	Addendum A to Equipment, Design, and Installation of Ammonia Mechanical Refrigerating Systems	1101.6

MSS

Manufacturers Standardization Society of the Valve & Fittings Industry, Inc.
127 Park Street, N.E.
Vienna, VA 22180

Standard Reference Number	Title	Referenced in code section number
SP-69—2002	Pipe Hangers and Supports—Selection and Application	305.4

NAIMA

North American Insulation Manufacturers Association
44 Canal Center Plaza, Suite 310
Alexandria, VA 22314

Standard Reference Number	Title	Referenced in code section number
AH116—02	Fibrous Glass Duct Construction Standards	603.5, 603.9

NFPA

National Fire Protection Association
1 Batterymarch Park
Quincy, MA 02169-7471

Standard Reference Number	Title	Referenced in code section number
30A—08	Code for Motor Fuel-dispensing Facilities and Repair Garages.	304.6
31—06	Installation of Oil-burning Equipment	801.2.1, 801.18.1, 801.18.2, 920.2, 922.1, 1308.1
37—06	Stationary Combustion Engines and Gas Turbines	915.1, 915.2
58—08	Liquefied Petroleum Gas Code	502.9.10
69—08	Explosion Prevention Systems	510.8.3
70—08	National Electrical Code	301.7, 306.3.1, 306.4.1, 511.1.1, 513.11, 513.12.1, 602.2.1.1, 1106.3, 1106.4
72—07	National Fire Alarm Code	606.3
82—04	Incinerators and Waste and Linen Handling Systems and Equipment	601.1
91—04	Exhaust Systems for Air Conveying of Vapors, Gases, and Noncombustible Particulate Solids	502.9.5.1, 502.17
92B—05	Smoke Management Systems in Malls, Atria and Large Spaces	513.8
211—06	Chimneys, Fireplaces, Vents and Solid Fuel-burning Appliances	806.1
262—07	Standard Method of Test for Flame Travel and Smoke of Wires and Cables for Use in Air-handling Spaces	602.2.1.1
704—07	Identification of the Hazards of Materials for Emergency Response	502.8.4, Table 1103.1, 510.1
853—07	Installation of Stationary Fuel Power Plants	924.1
8501—97	Single Burner Boiler Operation	1004.1
8502—99	Prevention of Furnace Explosions/Implosions in Multiple Burner Boiler-furnaces	1004.1
8504—96	Atmospheric Fluidized-bed Boiler Operation	1004.1

REFERENCED STANDARDS



Sheet Metal & Air Conditioning Contractors National Assoc., Inc.
4201 Lafayette Center Drive
Chantilly, VA 20151-1209

Standard Reference Number	Title	Referenced in code section number
SMACNA/ANSI—2005	HVAC Duct Construction Standards—Metal and Flexible (2005)	603.4, 603.9
SMACNA—03	Fibrous Glass Duct Construction Standards	603.5, 603.9



Underwriters Laboratories, Inc.
333 Pfingsten Road
Northbrook, IL 60062-2096

Standard Reference Number	Title	Referenced in code section number
17—94	Vent or Chimney Connector Dampers for Oil-fired Appliances—with Revisions through September 1999	803.6
103—01	Factory-built Chimneys, Residential Type and Building Heating Appliance—with Revisions through June 2006	805.2
127—96	Factory-built Fireplaces—with Revisions through November 2006	805.3, 903.1, 903.3
174—04	Household Electric Storage Tank Water Heaters—with Revisions through May 2006	1002.1
181—05	Factory-made Air Ducts and Air Connectors—with Revisions through December 1998	512.2, 603.5, 603.6.1, 603.6.2, 604.13
181A—05	Closure Systems for Use with Rigid Air Ducts and Air Connectors—with Revisions through December 1998	603.9
181B—05	Closure Systems for Use with Flexible Air Ducts and Air Connectors—with Revisions through December 1998	603.9
207—01	Refrigerant-containing Components and Accessories, Nonelectrical—with Revisions through November 2004	1101.2
263—03	Standard for Fire Test of Building Construction and Materials	607.5.2, 607.5.5, 607.6.1
268—06	Smoke Detectors for Fire Prevention Signaling Systems—with Revisions through October 2003	606.1
268A—98	Smoke Detectors for Duct Applications—with Revisions through April 2006	606.1
343—97	Pumps for Oil-Burning Appliances—with Revisions through May 2006	1302.7
391—2006	Solid-fuel and Combination-fuel Central and Supplementary Furnaces	918.1
412—04	Refrigeration Unit Coolers—with Revisions through February 2007	1101.2
471—06	Commercial Refrigerators and Freezers—with Revisions through March 2006	1101.2
508—99	Industrial Control Equipment—with Revisions through July 2005	307.2.3
536—97	Flexible Metallic Hose—with Revisions through June 2003	1302.8
555—06	Fire Dampers—with Revisions through January 2002	607.3
555C—06	Ceiling Dampers	607.3.1
555S—99	Smoke Dampers—with Revisions through July 2006	607.3.1
586—96	High-efficiency, Particulate, Air Filter Units—with Revisions through August 2004	605.2
641—95	Type L Low-temperature Venting Systems—with Revisions through August 2005	802.1
710—95	Exhaust Hoods for Commercial Cooking Equipment—with Revisions through February 2007	507.1
710B—04	Recirculating Systems	507.1
723—03	Standard for Test for Surface Burning Characteristics of Building Materials—with Revisions through May 2005	510.8, 602.2.1, 602.2.1.5, 604.3, 1204.1
726—95	Oil-fired Boiler Assemblies—with Revisions through March 2006	916.1, 1004.1
727—06	Oil-fired Central Furnaces	918.1
729—03	Oil-fired Floor Furnaces—with Revisions through January 1999	910.1
730—03	Oil-fired Wall Furnaces—with Revisions through January 1999	909.1
731—95	Oil-fired Unit Heaters—with Revisions through February 2006	920.1
732—95	Oil-fired Storage Tank Water Heaters—with Revisions through February 2005	1002.1
737—96	Fireplace Stoves—with Revisions through January 2000	905.1
762—03	Outline of Investigation for Power Ventilators for Restaurant Exhaust Appliances	506.5.1
791—06	Residential Incinerators	907.1
834—04	Heating, Water Supply and Power Boilers Electric—with Revisions through March 2006	1004.1
858—05	Household Electric Ranges—with Revisions through April 2006	917.1
867—00	Electrostatic Air Cleaners—with Revisions through May 2004	605.2
875—04	Electric Dry Bath Heater—with Revisions through March 2006	914.2
896—93	Oil-burning Stoves—with Revisions through May 2004	917.1, 922.1
900—04	Air Filter Units	605.2
923—02	Microwave Cooking Appliances—with Revisions through February 2006	914.2

UL—continued

959—01	Medium Heat Appliance Factory-built Chimneys—with Revisions through September 2006	805.5
1240—05	Electric Commercial Clothes913.1
1261—01	Electric Water Heaters for Pools and Tubs—with Revisions through June 2004.916.1
1453—04	Electric Booster and Commercial Storage Tank Water Heaters—with Revisions through May 2006.	1002.1
1482—96	Solid-fuel Type Room Heaters—with Revisions through November 2006905.1
1777—04	Chimney Liners801.16.1, 801.18.4
1812—05	Standard for Ducted Heat Recovery Ventilators—with Revisions through January 2006927.1
1815—01	Standard for Nonducted Heat Recovery Ventilators—with Revisions through January 2006927.2
1820—04	Fire Test of Pneumatic Tubing for Flame and Smoke Characteristics602.2.1.3
1887—04	Fire Tests of Plastic Sprinkler Pipe for Visible Flame and Smoke Characteristics602.2.1.2
1978—95	Grease Ducts506.3.2
1995—05	Heating and Cooling Equipment911.1, 918.1, 918.3, 1101.2
2158—97	Electric Clothes Dryers—with Revisions through May 2004504.6.3, 913.1
2162—01	Outline of Investigation for Commercial Wood-fired Baking Ovens—Refractory Type917.1
2200—04	Stationery Engine Generator Assemblies915.1
2221—01	Tests of Fire Resistive Grease Duct Enclosure Assemblies506.3.10.3

