

2018

NORTH CAROLINA STATE BUILDING CODE:

FIRE CODE

(2015 IFC® with
North Carolina Amendments)



2018 North Carolina Fire Code

First Printing: May 2018

ISBN: 978-1-60983-826-3

COPYRIGHT © 2018
by
INTERNATIONAL CODE COUNCIL, INC.

ALL RIGHTS RESERVED. This 2018 *North Carolina Fire Code* contains substantial material from the 2015 *International Fire Code*®, fourth printing, which is a copyrighted work owned by the International Code Council, Inc. Without advance written permission from the copyright owner, no part of this book may be reproduced, distributed or transmitted in any form or by any means, including, without limitation, electronic, optical or mechanical means (by way of example, and not limitation, photocopying or recording by or in an information storage retrieval system). For information on use rights and permissions, please contact: ICC Publications, 4051 Flossmoor Road, Country Club Hills, IL 60478. Phone 1-888-ICC-SAFE (422-7233).

Trademarks: “International Code Council,” the “International Code Council” logo, “ICC,” the “ICC” logo, “International Fire Code,” “IFC” and other names and trademarks appearing in this book are trademarks of the International Code Council, Inc., and/or its licensors (as applicable), and may not be used without permission.

Cover photo courtesy of Jeffery Clare.

PRINTED IN THE U.S.A.

**NORTH CAROLINA STATE BUILDING CODE COUNCIL
DECEMBER 12, 2017
www.ncbuildingcodes.com**

Charles Conner, RA — 22
(Architect)
Hager Smith Design
300 South Dawson Street
Raleigh, NC 27601
919-838-5104

Gary Embler — 23
(Home Builder)
Niblock Homes
759 Concord Pkwy N, Ste. 20
Concord, NC 28057
704-361-7720

Ralph Euchner — 19
(Gas Industry)
PSNC Energy
PO Box 1398
Gastonia, NC 28053
704-810-3331

Keith Hamilton — 19
(Mechanical Contractor)
Element Service Group
7414 Almaden Way
Cary, NC 27518
919-926-1475

Wayne Hamilton — 21
(Fire Services)
Buncombe County
270 Upper Herron Cove Road
Weaverville, NC 28787
828-658-3911

CHAIR

Robbie Davis — 21
(General Contractor)
Turn-Key Contractors
5998 Dortches Boulevard
Rocky Mount, NC 27804
252-977-6680

Bridget Herring — 23
(Public Representative)
Energy Program Coordinator
PO Box 7148
Asheville, NC 28802
828-484-4852

Steve Knight, PE — 21
(Structural Engineer)
Steve L. Knight, PE
1507 Mount Vernon Ave.
Statesville, NC 28677
704-878-2996

Frankie Meads — 22
(County Representative)
Albemarle Home Builders
200 Bayshore Drive
Elizabeth City, NC 27909
252-330-2423

Robert Morrow — 19
(Electrical Contractor)
Electrical Contractor
PO Box 1121
Pilot Mountain, NC 27041
336-420-7231

Keith Rogers, PE — 21
(Mechanical Engineer)
Bass, Nixon and Kennedy
6310 Chapel Hill Road, Ste. 250
Raleigh, NC 27612
919-851-4422

VICE CHAIR

Daniel Priest, RA — 22
(Architect)
Priest Architecture
PO Box 5295
Charlotte, NC 28299
704-379-1810

Tony Sears — 22
(Municipal Representative)
Kinston
PO Drawer 339
Kinston, NC 28502
252-939-3111

Leon Skinner — 21
(Building Inspector)
Raleigh
1 Exchange Plaza, Ste. 500
Raleigh, NC 27601
919-996-2455

David Smith — 22
(Coastal Contractor)
D. Smith Builder
905 Saltwood Lane
Wilmington, NC 28411
910-681-0394

Eric Tjalma, RA — 23
(State Agency)
State Construction
301 North Wilmington St.
Raleigh, NC 27601
919-807-4097

Wade White, PE — 19
(Electrical Engineer)
Brite Engineering
2001 Old Westfield Road
Pilot Mountain, NC 27041
336-351-3781

NORTH CAROLINA DEPARTMENT OF INSURANCE

www.ncdoi.com/osfm

919-647-0000

By Statute, the Commissioner of Insurance has general supervision of the administration and enforcement of the *North Carolina State Building Code* and the Engineering Division serves as the Staff for the Building Code Council. Officials of the Department of Insurance are:

MIKE CAUSEY
Commissioner

BRIAN TAYLOR
Senior Deputy Commissioner

CLIFF ISAAC, PE
Deputy Commissioner

BARRY GUPTON, PE
Chief Code Consultant

DAN AUSTIN
Fire Code Consultant

COMMITTEES OF THE COUNCIL DECEMBER 12, 2017

ADMINISTRATION

Robbie Davis — Chair
Daniel Priest, RA - Vice Chair
Ralph Euchner
Wayne Hamilton
Steve Knight, PE
Keith Rogers, PE
Leon Skinner
David Smith
Wade White, PE

BUILDING

Daniel Priest, RA — Chair
Charles Conner, RA
Wayne Hamilton
Steve Knight, PE
Tony Sears
Leon Skinner
Eric Tjalma, RA

ELECTRICAL

Wade White, PE — Chair
Ralph Euchner
Bridget Herring
Robert Morrow
Daniel Priest, RA
Keith Rogers, PE

ENERGY

Ralph Euchner — Chair
Charles Conner, RA
Steve Knight, PE
Frankie Meads
Bridget Herring
Tony Sears
David Smith
Eric Tjalma, RA

EXISTING BUILDING

Leon Skinner — Chair
Keith Hamilton
Wayne Hamilton
Steve Knight, PE
Robert Morrow
Daniel Priest, RA
Wade White, PE

FIRE PREVENTION

Wayne Hamilton — Chair
Charles Conner, RA
Ralph Euchner
Daniel Priest, RA
Leon Skinner
Wade White, PE

MECHANICAL

Keith Rogers, PE — Chair
Ralph Euchner
Keith Hamilton
Bridget Herring
Robert Morrow
David Smith
Eric Tjalma, RA
Wade White, PE

RESIDENTIAL

David Smith — Chair
Charles Conner, RA
Ralph Euchner
Keith Hamilton
Steve Knight, PE
Frankie Meads
Robert Morrow
Leon Skinner

STRUCTURAL

Steve Knight, PE — Chair
Frankie Meads
Daniel Priest, RA
Keith Rogers, PE
Tony Sears
Leon Skinner
Eric Tjalma, RA

ACKNOWLEDGEMENTS

North Carolina Building Code Council

Fire Code Ad-Hoc Committee

CHAIR

Dan Austin
NC Department of Insurance
1202 Mail Service Center
Raleigh, NC 27699

Betsy Bailey
Carolinas Association of General Contractors
6115 Park South Drive, Ste. 350
Charlotte, NC 28210

Robbie Davis
Turn-Key Contractors
5998 Dortches Boulevard
Rocky Mount, NC 27804

Wayne Hamilton
Asheville Fire Service
PO Box 7148
Asheville, NC 28802

Jeff Johnson
Jeff Johnson Consulting, Inc.
225 Red Hill Lane
New Hill, NC 27562

Carl P. Martin
NC Department of Insurance
1202 Mail Service Center
Raleigh, NC 27699

Robbie M. Pate (Retired)
3620 Joyner Road.
Elm City, NC 27822

Daniel Priest
Priest Architecture
PO Box 5295
Charlotte, NC 28299

Bryan Robinson
City of Raleigh
One Exchange Plaza
Raleigh, NC 27602

Dan Tingen
Tingen Construction Company, Inc.
8411-101 Garvey Drive
Raleigh, NC 27616

PREFACE

Introduction

Internationally, code officials recognize the need for a modern, up-to-date fire code addressing conditions hazardous to life and property from fire, explosion, handling or use of hazardous materials and the use and occupancy of buildings and premises. The *International Fire Code*®, in this 2015 edition, is designed to meet these needs through model code regulations that safeguard the public health and safety in all communities, large and small.

This comprehensive fire code establishes minimum regulations for fire prevention and fire protection systems using prescriptive and performance-related provisions. It is founded on broad-based principles that make possible the use of new materials and new system designs. This 2015 edition is fully compatible with all of the *International Codes*® (I-Codes®) published by the International Code Council (ICC)®, including the *International Building Code*®, *International Energy Conservation Code*®, *International Existing Building Code*®, *International Fuel Gas Code*®, *International Green Construction Code*®, *International Mechanical Code*®, *ICC Performance Code*®, *International Plumbing Code*®, *International Private Sewage Disposal Code*®, *International Property Maintenance Code*®, *International Residential Code*®, *International Swimming Pool and Spa Code*®, *International Wildland-Urban Interface Code*® and *International Zoning Code*®.

The *International Fire Code* provisions provide many benefits, among which is the model code development process that offers an international forum for fire safety professionals to discuss performance and prescriptive code requirements. This forum provides an excellent arena to debate proposed revisions. This model code also encourages international consistency in the application of provisions.

Development

The first edition of the *International Fire Code* (2000) was the culmination of an effort initiated in 1997 by a development committee appointed by ICC and consisting of representatives of the three statutory members of the International Code Council: Building Officials and Code Administrators International, Inc. (BOCA), International Conference of Building Officials (ICBO) and Southern Building Code Congress International (SBCCI). The intent was to draft a comprehensive set of fire safety regulations consistent with and inclusive of the scope of the existing model codes. Technical content of the latest model codes promulgated by BOCA, ICBO and SBCCI was utilized as the basis for the development, followed by public hearings in 1998 and 1999 to consider proposed changes. This 2015 edition presents the code as originally issued, with changes reflected in the 2003, 2006, 2009 and 2012 editions and further changes approved through the ICC Code Development Process through 2014. A new edition such as this is promulgated every 3 years.

This code is founded on principles intended to establish provisions consistent with the scope of a fire code that adequately protects public health, safety and welfare; provisions that do not unnecessarily increase construction costs; provisions that do not restrict the use of new materials, products or methods of construction; and provisions that do not give preferential treatment to particular types or classes of materials, products or methods of construction.

Adoption

The International Code Council maintains a copyright in all of its codes and standards. Maintaining copyright allows ICC to fund its mission through sales of books, in both print and electronic formats. The *International Fire Code* is designed for adoption and use by jurisdictions that recognize and acknowledge the ICC's copyright in the code, and further acknowledge the substantial shared value of the public/private partnership for code development between jurisdictions and the ICC.

The ICC also recognizes the need for jurisdictions to make laws available to the public. All ICC codes and ICC standards, along with the laws of many jurisdictions, are available for free in a non-downloadable form on the ICC's website. Jurisdictions should contact the ICC at adoptions@iccsafe.org to learn how to adopt and distribute laws based on the *International Fire Code* in a manner that provides necessary access, while maintaining the ICC's copyright.

Maintenance

The *International Fire Code* is kept up to date through the review of proposed changes submitted by code enforcing officials, industry representatives, design professionals and other interested parties. Proposed changes are carefully considered through an open code development process in which all interested and affected parties may participate.

The contents of this work are subject to change through both the code development cycles and the governmental body that enacts the code into law. For more information regarding the code development process, contact the Codes and Standards Development Department of the International Code Council.

While the development procedure of the *International Fire Code* ensures the highest degree of care, the ICC, its members and those participating in the development of this code do not accept any liability resulting from compliance or noncompliance with the provisions because the ICC does not have the power or authority to police or enforce compliance with the contents of this code. Only the governmental body that enacts the code into law has such authority.

Code Development Committee Responsibilities (Letter Designations in Front of Section Numbers)

In each code development cycle, proposed changes to the code are considered at the Committee Action Hearings by the International Fire Code Development Committee, whose action constitutes a recommendation to the voting membership for final action on the proposed change. Proposed changes to a code section that has a number beginning with a letter(s) in brackets are considered by a different code development committee. For example, proposed changes to code sections that have [BE] in front of them (e.g., [BE] 607.3) are considered by the appropriate International Building Code Development Committee (IBC – Means of Egress) at the code development hearings.

The content of sections in this code that begin with a letter designation is maintained by another code development committee in accordance with the following:

- [A] = Administrative Code Development Committee;
- [BE] = IBC – Means of Egress Code Development Committee;
- [BF] = IBC – Fire Safety Code Development Committee;
- [BG] = IBC – General Code Development Committee;
- [BS] = IBC – Structural Code Development Committee;
- [EB] = International Existing Building Code Development Committee;
- [FG] = International Fuel Gas Code Development Committee;
- [M] = International Mechanical Code Development Committee; and
- [P] = International Plumbing Code Development Committee.

Marginal and Text Markings

Solid vertical lines in the margins within the body of the code indicate a technical change from the requirements of the 2012 edition. Deletion indicators in the form of an arrow (➡) are provided in the margin where an entire section, paragraph, exception or table has been deleted or an item in a list of items or a table has been deleted. Underlining within the body of the code indicates a technical change to the 2018 North Carolina Fire Code from the requirements of the 2015 edition of the International Fire Code.

A single asterisk [*] placed in the margin indicates that text or a table has been relocated within the code. A double asterisk [**] placed in the margin indicates that the text or table immediately following it has been relocated there from elsewhere in the code. The following table indicates such relocations in the 2015 edition of the *International Fire Code*.

2012 LOCATION	2015 LOCATION
408.11.3	311.6
408	403
903.3.5.2	914.3.2
908.7	915
1014.3, 1015, 1021	1006
1015.2, 1021.3	1007
1009.3	1019
2311.8	2309.6

Coordination between the International Building and Fire Codes

Because the coordination of technical provisions is one of the benefits of adopting the ICC family of model codes, users will find the ICC codes to be a very flexible set of model documents. To accomplish this flexibility some technical provisions are duplicated in some of the model code documents. While the *International Codes* are provided as a comprehensive set of model codes for the built environment, documents are occasionally adopted as a stand-alone regulation. When one of the model documents is adopted as the basis of a stand-alone code, that code should provide a complete package of requirements with enforcement assigned to the entity for which the adoption is being made.

The model codes can also be adopted as a family of complementary codes. When adopted together there should be no conflict of any of the technical provisions. When multiple model codes are adopted in a jurisdiction it is important for the adopting authority to evaluate the provisions in each code document and determine how and by which agency(ies) they will be enforced. It is important, therefore, to understand that where technical provisions are duplicated in multiple model documents that enforcement duties must be clearly assigned by the local adopting jurisdiction. ICC remains committed to providing state-of-the-art model code documents that, when adopted locally, will reduce the cost to government of code adoption and enforcement and protect the public health, safety and welfare.

Italicized Terms

Selected terms set forth in Chapter 2, Definitions, are italicized where they appear in code text. Such terms are not italicized where the definition set forth in Chapter 2 does not impart the intended meaning in the use of the term. The terms selected have definitions that the user should read carefully to better understand the code.

EFFECTIVE USE OF THE INTERNATIONAL FIRE CODE

The *International Fire Code*® (IFC®) is a model code that regulates minimum fire safety requirements for new and existing buildings, facilities, storage and processes. The IFC addresses fire prevention, fire protection, life safety and safe storage and use of hazardous materials in new and existing buildings, facilities and processes. The IFC provides a total approach of controlling hazards in all buildings and sites, regardless of the hazard being indoors or outdoors.

The IFC is a design document. For example, before one constructs a building, the site must be provided with an adequate water supply for fire-fighting operations and a means of building access for emergency responders in the event of a medical emergency, fire or natural or technological disaster. Depending on the building's occupancy and uses, the IFC regulates the various hazards that may be housed within the building, including refrigeration systems, application of flammable finishes, fueling of motor vehicles, high-piled combustible storage and the storage and use of hazardous materials. The IFC sets forth minimum requirements for these and other hazards and contains requirements for maintaining the life safety of building occupants, the protection of emergency responders, and to limit the damage to a building and its contents as the result of a fire, explosion or unauthorized hazardous material discharge.

Arrangement and Format of the 2015 IFC

Before applying the requirements of the IFC it is beneficial to understand its arrangement and format. The IFC, like other codes published by the International Code Council, is arranged and organized to follow sequential steps that generally occur during a plan review or inspection. In the 2012 edition, the IFC was reorganized into seven parts as illustrated in the tables below. Each part represents a broad subject matter and includes the chapters that logically fit under the subject matter of each part. It is also foreseeable that additional chapters will need to be added in the future as regulations for new processes or operations are developed. Accordingly, the reorganization was designed to accommodate such future chapters by providing reserved (unused) chapters in several of the parts. This will allow the subject matter parts to be conveniently and logically expanded without requiring a major renumbering of the IFC chapters.

ORGANIZATION OF THE IFC	
Parts and Chapters	Subject Matter
Part I – Chapters 1 and 2	Administrative and definitions
Part II – Chapters 3 and 4	General safety provisions
Part III – Chapters 5 through 11	Building and equipment design features
Part III – Chapters 12 through 19	Reserved for future use
Part IV – Chapters 20 through 37	Special occupancies and operations
Part IV – Chapters 38 through 49; 52	Reserved for future use
Part V – Chapters 50, 51 and 53 through 67	Hazardous materials
Part V – Chapters 68 through 79	Reserved for future use
Part VI – Chapter 80	Referenced standards
Part VII – Appendices A through M	Adoptable and informational appendices

The IFC requirements for fire-resistive construction, interior finish, fire protection systems, means of egress and construction safeguards are directly correlated to the chapters containing parallel requirements in the IBC, as follows:

IFC Chapter	Subject
7	Fire and smoke protection features
8	Interior finish, decorative materials and furnishings
9	Fire protection systems
10	Means of egress
33	Fire safety during construction and demolition

The following is a chapter-by-chapter synopsis of the scope and intent of the provisions of the *International Fire Code*:

PART I—ADMINISTRATIVE

Chapter 1 Scope and Administration. This chapter contains provisions for the application, enforcement and administration of subsequent requirements of the code. In addition to establishing the scope of the code, Chapter 1 identifies which buildings and structures come under its purview. Chapter 1 is largely concerned with maintaining “due process of law” in enforcing the regulations contained in the body of the code. Only through careful observation of the administrative provisions can the code official reasonably expect to demonstrate that “equal protection under the law” has been provided.

Chapter 2 Definitions. All terms that are defined in the code are listed alphabetically in Chapter 2. While a defined term may be used in one chapter or another, the meaning provided in Chapter 2 is applicable throughout the code.

Where understanding of a term’s definition is especially key to or necessary for understanding of a particular code provision, the term is shown in *italics* wherever it appears in the code. This is true only for those terms that have a meaning that is unique to the code. In other words, the generally understood meaning of a term or phrase might not be sufficient or consistent with the meaning prescribed by the code; therefore, it is essential that the code-defined meaning be known.

Guidance regarding tense, gender and plurality of defined terms as well as guidance regarding terms not defined in this code are also provided.

PART II—GENERAL SAFETY PROVISIONS

Chapter 3 General Requirements. The open burning, ignition source, vacant building, miscellaneous storage, roof gardens and landscaped roofs, and hazards to fire fighters requirements and precautions, among other general regulations contained in this chapter, are intended to improve premises safety for everyone, including construction workers, tenants, operations and maintenance personnel, and emergency response personnel. As with other chapters of the *International Fire Code*, Section 302 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 4 Emergency Planning and Preparedness. This chapter addresses the human contribution to life safety in buildings when a fire or other emergency occurs. The requirements for continuous training and scheduled fire, evacuation and lockdown drills can be as important as the required periodic inspections and maintenance of built-in fire protection features. The level of preparation by the occupants also improves the emergency responders’ abilities during an emergency. The *International Building Code* (IBC) focuses on built-in fire protection features, such as automatic sprinkler systems, fire-resistance-rated construction and properly designed egress systems, whereas this chapter fully addresses the human element. As with other chapters of the *International Fire Code*, Section 402 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

PART III—BUILDING AND EQUIPMENT DESIGN FEATURES

Chapter 5 Fire Service Features. The requirements of this chapter apply to all buildings and occupancies and pertain to access roads; access to building openings and roofs; premises identification; key boxes; fire protection water supplies; fire command centers; fire department access to equipment and emergency responder radio coverage in buildings. As with other chapters of the *International Fire Code*, Section 502 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 6 Building Services and Systems. This chapter focuses on building systems and services as they relate to potential safety hazards and when and how they should be installed. This chapter brings together all building system- and service-related issues for convenience and provides a more systematic view of buildings. The following building services and systems are addressed: fuel-fired appliances (Section 603), emergency and standby power systems (Section 604), electrical equipment, wiring and hazards (Section 605), mechanical refrigeration (Section 606), elevator recall and maintenance (Section 607), stationary storage battery systems (Section 608), commercial kitchen hoods (Section 609), commercial kitchen cooking oil storage (610) and hyperbaric facilities (611). As with other chapters of the *International Fire Code*, Section 602 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 7 Fire and Smoke Protection Features. The maintenance of assemblies required to be fire-resistance rated is a key component in a passive fire protection philosophy. Chapter 7 sets forth requirements to maintain required fire-resistance ratings of building elements and limit fire spread. The required maintenance of fire-resistance-rated assemblies and opening protectives is described in Section 703 while Section 704 covers the enclosure requirements for shafts in existing buildings. As with other chapters of the *International Fire Code*, Section 702 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 8 Interior Finish, Decorative Materials and Furnishings. The overall purpose of Chapter 8 is to regulate interior finishes, decorative materials and furnishings in new and existing buildings so that they do not significantly add to or create fire hazards within buildings. The provisions tend to focus on occupancies with specific risk characteristics, such as vulnerability of occupants, density of occupants, lack of familiarity with the building and societal expectations of importance. This chapter is consistent with Chapter 8 of the *International Building Code* (IBC), which regulates the interior finishes of new buildings. As with other chapters of the *International Fire Code*, Section 802 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 9 Fire Protection Systems. Chapter 9 prescribes the minimum requirements for active systems of fire protection equipment to perform the functions of detecting a fire, alerting the occupants or fire department of a fire emergency, controlling smoke and controlling or extinguishing the fire. Generally, the requirements are based on the occupancy, the height and the area of the building, because these are the factors that most affect fire-fighting capabilities and the relative hazard of a specific building or portion thereof. This chapter parallels and is substantially duplicated in Chapter 9 of the *International Building Code*; however, this chapter also contains periodic testing criteria that are not contained in the IBC. In addition, the special fire protection system requirements based on use and occupancy found in Chapter 4 of the IBC are duplicated in Chapter 9 of the IFC as a user convenience. As with other chapters of the *International Fire Code*, Section 902 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 10 Means of Egress. The general criteria set forth in Chapter 10 regulating the design of the means of egress are established as the primary method for protection of people in buildings by allowing timely relocation or evacuation of building occupants. Both prescriptive and performance language is utilized in this chapter to provide for a basic approach in the determination of a safe exiting system for all occupancies. It addresses all portions of the egress system (i.e., exit access, exits and exit discharge) and includes design requirements as well as provisions regulating individual components. The requirements detail the size, arrangement, number and protection of means of egress components. Functional and operational characteristics also are specified for the components that will permit their safe use without special knowledge or effort. The means of egress protection requirements work in coordination with other sections of the code, such as protection of vertical openings (see Chapter 7), interior finish (see Chapter 8), fire suppression and detection systems (see Chapter 9) and numerous others, all having an impact on life safety. Sections 1002 through 1030 are duplicated text from Chapter 10 of the IBC; however, the IFC contains an additional Section 1031 on maintenance of the means of egress system in existing buildings. Retroactive minimum means of egress requirements for existing buildings are found in Chapter 11. As with other chapters of the *International Fire Code*, Section 1002 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 11 Construction Requirements for Existing Buildings. Deleted.

Chapters 12 through 19. Reserved for future use.

PART IV—SPECIAL OCCUPANCIES AND OPERATIONS

Chapter 20 Aviation Facilities. Chapter 20 specifies minimum requirements for the fire-safe operation of airports, heliports and helistops. The principal nonflight operational hazards associated with aviation involve fuel, facilities and operations. Therefore, safe use of flammable and combustible liquids during fueling and maintenance operations is emphasized. Availability of portable Class B:C-rated fire extinguishers for prompt control or suppression of incipient fires is required. As with other chapters of the *International Fire Code*, Section 2002 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 21 Dry Cleaning. The provisions of Chapter 21 are intended to reduce hazards associated with use of flammable and combustible dry cleaning solvents. These materials, like all volatile organic chemicals, generate significant quantities of static electricity and are thus readily ignitable. Many flammable and nonflammable dry cleaning solvents also possess health hazards when involved in a fire. As with other chapters of the *International Fire Code*, Section 2102 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 22 Combustible Dust-producing Operations. The requirements of Chapter 22 seek to reduce the likelihood of dust explosions by managing the hazards of ignitable suspensions of combustible dusts associated with a variety of operations including woodworking, mining, food processing, agricultural commodity storage and handling and pharmaceutical manufacturing, among others. Ignition source control and good housekeeping practices in occupancies containing dust-producing operations are emphasized. As with other chapters of the *International Fire Code*, Section 2202 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 23 Motor Fuel-dispensing Facilities and Repair Garages. This chapter provides provisions that regulate the storage and dispensing of both liquid and gaseous motor fuels at public and private automotive, marine and aircraft motor fuel-dispensing facilities, fleet vehicle motor fuel-dispensing facilities and repair garages. As with other chapters of the *International Fire Code*, Section 2302 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 24 Flammable Finishes. Chapter 24 requirements govern operations where flammable or combustible finishes are applied by spraying, dipping, powder coating or flow-coating processes. As with all operations involving flammable or combustible liquids and combustible dusts or vapors, controlling ignition sources and methods of reducing or controlling flammable vapors or combustible dusts at or near these operations are emphasized. As with other chapters of the *International Fire Code*, Section 2402 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 25 Fruit and Crop Ripening. Chapter 25 provides guidance that is intended to reduce the likelihood of explosions resulting from improper use or handling of ethylene gas used for crop-ripening and coloring processes. This is accomplished by regulating ethylene gas generation; storage and distribution systems and controlling ignition sources. Design and construction of facilities for this use are regulated by the *International Building Code* to reduce the impact of potential accidents on people and buildings.

Chapter 26 Fumigation and Insecticidal Fogging. This chapter regulates fumigation and insecticidal fogging operations which use toxic pesticide chemicals to kill insects, rodents and other vermin. Fumigants and insecticidal fogging agents pose little hazard if properly applied; however, the inherent toxicity of all these agents and the potential flammability of some makes special precautions necessary when they are used. Requirements of this chapter are intended to protect both the public and fire fighters from hazards associated with these products. As with other chapters of the *International Fire Code*, Section 2602 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 27 Semiconductor Fabrication Facilities. The requirements of this chapter are intended to control hazards associated with the manufacture of electrical circuit boards or microchips, commonly called semiconductors. Though the finished product possesses no unusual hazards, materials commonly associated with semiconductor manufacturing are often quite hazardous and include flammable liquids, pyrophoric and flammable gases, toxic substances and corrosives. The requirements of this chapter are concerned with both life safety and property protection. However, the fire code official should recognize that the risk of extraordinary property damages is far more common than the risk of personal injuries from fire. As with other chapters of the *International Fire Code*, Section 2702 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 28 Lumber Yards and Agro-industrial, Solid Biomass and Woodworking Facilities. Provisions of this chapter are intended to prevent fires and explosions, facilitate fire control and reduce exposures to and from facilities storing, selling or processing wood and forest products, including sawdust, wood chips, shavings, bark mulch, shorts, finished planks, sheets, posts, poles, timber and raw logs and the hazard they represent once ignited. Also included are solid biomass feedstock and raw products associated with agro-industrial facilities. This chapter requires active and passive fire protection features to reduce on- and off-site exposures, limit fire size and development and facilitate fire fighting by employees and the fire service. As with other chapters of the *International Fire Code*, Section 2802 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 29 Manufacture of Organic Coatings. This chapter regulates materials and processes associated with the manufacture of paints as well as bituminous, asphaltic and other diverse compounds formulated to protect buildings, machines and objects from the effects of weather, corrosion and hostile environmental exposures. Paint for decorative, architectural and industrial uses comprises the bulk of organic coating production. Painting and processes related to the manufacture of nonflammable and noncombustible or water-based products are exempt from the provisions of this chapter. The application of organic coatings is covered by Chapter 24. Elimination of ignition sources, maintenance of fire protection equipment and isolation or segregation of hazardous operations are emphasized. As with other chapters of the *International Fire Code*, Section 2902 contains a term that is defined in Chapter 2 and is applicable to the chapter contents.

Chapter 30 Industrial Ovens. This chapter addresses the fuel supply, ventilation, emergency shutdown equipment, fire protection and the operation and maintenance of industrial ovens, which are sometimes referred to as industrial heat enclosures or industrial furnaces. Compliance with this chapter is intended to reduce the likelihood of fires involving industrial ovens which are usually the result of the fuel in use or volatile vapors given off by the materials being heated or to manage the impact if a fire should occur. As with other chapters of the *International Fire Code*, Section 3002 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 31 Tents and Other Membrane Structures. The requirements in this chapter are intended to protect temporary as well as permanent tents and air-supported and other membrane structures and temporary stage canopies from fire and similar hazards by regulating structure location and access, anchorage, egress, heat-producing equipment, hazardous materials and operations, combustible vegetation, ignition sources, waste accumulation and requiring regular inspections and certifying continued compliance with fire safety regulations. As with other chapters of the *International Fire Code*, Section 3102 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 32 High-piled Combustible Storage. This chapter provides guidance for reasonable protection of life from hazards associated with the storage of combustible materials in closely packed piles or on pallets, in racks or on shelves where the top of storage is greater than 12 feet in height. It provides requirements for identifying various classes of commodities; general fire and life safety features including storage arrangements, smoke and heat venting, fire department access and housekeeping and maintenance requirements. The chapter attempts to define the potential fire severity and, in turn, determine fire and life safety protection measures needed to control, and in some cases suppress, a potential fire. This chapter does not cover miscellaneous combustible materials storage regulated in Section 315. As with other chapters of the *International Fire Code*, Section 3202 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 33 Fire Safety during Construction and Demolition. Chapter 33 outlines general fire safety precautions for all structures and all occupancies during construction and demolition operations. In general, these requirements seek to maintain required levels of fire protection, limit fire spread, establish the appropriate operation of equipment and promote prompt response to fire emergencies. Features regulated include fire protection systems, fire fighter access to the site and building, means of egress, hazardous materials storage and use and temporary heating equipment and other ignition sources. With the 2012 reorganization, this chapter now correlates with Chapter 33 of the IBC.

Chapter 34 Tire Rebuilding and Tire Storage. The requirements of Chapter 34 are intended to prevent or control fires and explosions associated with the remanufacture and storage of tires and tire byproducts. Additionally, the requirements are intended to minimize the impact of indoor and outdoor tire storage fires by regulating pile volume and location, segregating the various operations, providing for fire department access and a water supply and controlling ignition sources.

Chapter 35 Welding and Other Hot Work. This chapter covers requirements for safety in welding and other types of hot work by reducing the potential for fire ignitions that usually result in large losses. Several different types of hot work would fall under the requirements found in Chapter 35, including both gas and electric arc methods and any open-torch operations. Many of the activities of this chapter focus on the actions of the occupants. As with other chapters of the *International Fire Code*, Section 3502 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 36 Marinas. Chapter 36 addresses the fire protection and prevention requirements for marinas. It was developed in response to the complications encountered by a number of fire departments responsible for the protection of marinas as well as fire loss history in marinas that lacked fire protection. Compliance with this chapter intends to establish safe practices in marina areas, provide an identification method for mooring spaces in the marina, provide fire fighters with safe operational areas and fire protection methods to extend hose lines in a safe manner. As with other chapters of the *International Fire Code*, Section 3602 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 37 Combustible Fibers. Chapter 37 (which was formerly Chapter 52) establishes the requirements for storage and handling of combustible fibers, including animal, vegetable and synthetic fibers, whether woven into textiles, baled, packaged or loose. Operations involving combustible fibers are typically associated with salvage, paper milling, recycling, cloth manufacturing, carpet and textile mills and agricultural operations, among others. The primary hazard associated with these operations is the abundance of materials and their ready ignitability. As with other chapters of the *International Fire Code*, Section 3702 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapters 38 through 49. Reserved for future use.

PART V—HAZARDOUS MATERIALS

Chapter 50 Hazardous Materials—General Provisions. This chapter contains the general requirements for all hazardous chemicals in all occupancies. Hazardous chemicals are defined as those that pose an unreasonable risk to the health and safety of operating or emergency personnel, the public and the environment if not properly controlled during handling, storage, manufacture, processing, packaging, use, disposal or transportation. The general provisions of this chapter are intended to be companion provisions with the specific requirements of Chapters 51 through 67 regarding a given hazardous material. As with other chapters of the *International Fire Code*, Section 5002 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 51 Aerosols. Chapter 51 addresses the prevention, control and extinguishment of fires and explosions in facilities where retail aerosol products are displayed or stored. It is concerned with both life safety and property protection from a fire; however, historically, aerosol product fires

have caused property loss more frequently than loss of life. Requirements for storing aerosol products are dependent on the level of aerosol product, level of sprinkler protection, type of storage condition and quantity of aerosol products. As with other chapters of the *International Fire Code*, Section 5102 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 52. Reserved for future use.

Chapter 53 Compressed Gases. This chapter regulates the storage, use and handling of all flammable and nonflammable compressed gases, such as those that are used in medical facilities, air separation plants, industrial plants, agricultural equipment and similar occupancies. Standards for the design, construction and marking of compressed gas cylinders and pressure vessels are referenced. Compressed gases used in welding and cutting, cryogenic liquids and liquefied petroleum gases are also regulated under Chapters 35, 55 and 61, respectively. Compressed gases that are classified as hazardous materials are also regulated in Chapter 50, which includes general requirements. As with other chapters of the *International Fire Code*, Section 5302 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 54 Corrosive Materials. Chapter 54 addresses the hazards of corrosive materials that have a destructive effect on living tissues. Though corrosive gases exist, most corrosive materials are solid and classified as either acids or bases (alkalis). These materials may pose a wide range of hazards other than corrosivity, such as combustibility, reactivity or oxidizing hazards, and must conform to the requirements of this code with respect to all their known hazards. The focus of this chapter is on materials whose primary hazard is corrosivity; that is, the ability to destroy or irreparably damage living tissue on contact. As with other chapters of the *International Fire Code*, Section 5402 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 55 Cryogenic Fluids. This chapter regulates the hazards associated with the storage, use and handling of cryogenic fluids through regulation of such things as pressure relief mechanisms and proper container storage. These hazards are in addition to the code requirements that address the other hazards of cryogenic fluids such as flammability and toxicity. These other characteristics are dealt with in Chapter 50 and other chapters, such as Chapter 58 dealing with flammable gases. Cryogens are hazardous because they are held at extremely low temperatures and high pressures. Many cryogenic fluids, however, are actually inert gases and would not be regulated elsewhere in this code. Cryogens are used for many applications but specifically have had widespread use in the biomedical field and in space programs. As with other chapters of the *International Fire Code*, Section 5502 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 56 Explosives and Fireworks. This chapter prescribes minimum requirements for the safe manufacture, storage, handling and use of explosives, ammunition and blasting agents for commercial and industrial occupancies. These provisions are intended to protect the general public, emergency responders and individuals who handle explosives. Chapter 56 also regulates the manufacturing, retail sale, display and wholesale distribution of fireworks, establishing the requirements for obtaining approval to manufacture, store, sell, discharge or conduct a public display, and references national standards for regulations governing manufacture, storage and public displays. As with other chapters of the *International Fire Code*, Section 5602 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 57 Flammable and Combustible Liquids. The requirements of this chapter are intended to reduce the likelihood of fires involving the storage, handling, use or transportation of flammable and combustible liquids. Adherence to these practices may also limit damage in the event of an accidental fire involving these materials. These liquids are used for fuel, lubricants, cleaners, solvents, medicine and even drinking. The danger associated with flammable and combustible liquids is that the vapors from these liquids, when combined with air in their flammable range, will burn or explode at temperatures near normal living and working environment. The protection provided by this code is to prevent the flammable and combustible liquids from being ignited. As with other chapters of the *International Fire Code*, Section 5702 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 58 Flammable Gases and Flammable Cryogenic Fluids. Chapter 58 sets requirements for the storage and use of flammable gases. For safety purposes, there is a limit on the quantities of flammable gas allowed per control area. Exceeding these limitations increases the possibility of damage to both property and individuals. The principal hazard posed by flammable gas is its ready ignitability, or even explosivity, when mixed with air in the proper proportions. Consequently, occupancies storing or handling large quantities of flammable gas are classified as Group H-2 (high hazard) by the *International Building Code*. As with other chapters of the *International Fire Code*, Section 5802 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 59 Flammable Solids. This chapter addresses general requirements for storage and handling of flammable solids, especially magnesium; however, it is important to note that several other solid materials, primarily metals including, but not limited to, such metals as titanium, zirconium, hafnium, calcium, zinc, sodium, lithium, potassium, sodium/potassium alloys, uranium, thorium and plutonium which, under the right conditions, can be explosion hazards. Some of these metals are almost exclusively laboratory materials but because of where they are used, fire service personnel must be trained to handle emergency situations. Because uranium, thorium and plutonium are also radioactive materials, they present still more specialized problems for fire service personnel. As with other chapters of the *International Fire Code*, Section 5902 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 60 Highly Toxic and Toxic Materials. The main purpose of this chapter is to protect occupants, emergency responders and those in the immediate area of the building and facility from short-term, acute hazards associated with a release or general exposure to toxic and highly toxic materials. This chapter deals with all three states of toxic and highly toxic materials: solids, liquids and gases. This code does not address long-term exposure effects of these materials, which are addressed by agencies such as the Environmental Protection Agency (EPA) and Occupational Safety and Health Administration (OSHA). As with other chapters of the *International Fire Code*, Section 6002 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 61 Liquefied Petroleum Gases. Chapter 61 establishes requirements for the safe handling, storing and use of LP-gas to reduce the possibility of damage to containers, accidental releases of LP-gas and exposure of flammable concentrations of LP-gas to ignition sources. LP-gas (notably propane) is well known as a camping fuel for cooking, lighting, heating and refrigerating and also remains a popular standby fuel supply for auxiliary generators as well as being widely used as an alternative motor vehicle fuel. Its characteristic as a clean-burning fuel having resulted in the addition of propane dispensers to service stations throughout the country. As with other chapters of the *International Fire Code*, Section 6102 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 62 Organic Peroxides. This chapter addresses the hazards associated with the storage, handling and use of organic peroxides and intends to manage the fire and oxidation hazards of organic peroxides by preventing their uncontrolled release. These chemicals possess the characteristics of flammable or combustible liquids and are also strong oxidizers. This unusual combination of properties requires special storage and handling precautions to prevent uncontrolled release, contamination, hazardous chemical reactions, fires or explosions. The requirements of this chapter pertain to industrial applications in which significant quantities of organic peroxides are stored or used; however, smaller quantities of organic peroxides still pose a significant hazard and, therefore, must be stored and used in accordance with the applicable provisions of this chapter and Chapter 50. As with other chapters of the *International Fire Code*, Section 6202 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 63 Oxidizers, Oxidizing Gases and Oxidizing Cryogenic Fluids. Chapter 63 addresses the hazards associated with solid, liquid, gaseous and cryogenic fluid oxidizing materials, including oxygen in home use, and establishes criteria for their safe storage and protection in indoor and outdoor storage facilities, minimizing the potential for uncontrolled releases and contact with fuel sources. Although oxidizers themselves do not burn, they pose unique fire hazards because of their ability to support combustion by breaking down and giving off oxygen. As with other chapters of the *International Fire Code*, Section 6302 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 64 Pyrophoric Materials. This chapter regulates the hazards associated with pyrophoric materials, which are capable of spontaneously igniting in the air at or below a temperature of 130°F (54°C). Many pyrophoric materials also pose severe flammability or reactivity hazards. This chapter addresses only the hazards associated with pyrophoric materials. Materials that pose multiple hazards must conform to the requirements of the code with respect to all hazards. As with other chapters of the *International Fire Code*, Section 6402 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 65 Pyroxylin (Cellulose Nitrate) Plastics. This chapter addresses the significant hazards associated with pyroxylin (cellulose nitrate) plastics, which are the most dangerous and unstable of all plastic compounds. The chemically bound oxygen in their structure permits them to burn vigorously in the absence of atmospheric oxygen at a rate 15 times greater than comparable common combustibles. Strict compliance with the provisions of this chapter, along with proper housekeeping and storage arrangements, helps to reduce the hazards associated with pyroxylin (cellulose nitrate) plastics in a fire or other emergencies.

Chapter 66 Unstable (Reactive) Materials. This chapter addresses the hazards of unstable (reactive) liquid and solid materials as well as unstable (reactive) compressed gases. In addition to their unstable reactivity, these materials may pose other hazards, such as toxicity, corrosivity, explosivity, flammability or oxidizing potential. This chapter, however, intends to address those materials whose primary hazard is unstable reactivity. Materials that pose multiple hazards must conform to the requirements of the code with respect to all hazards. Strict compliance with the provisions of this chapter, along with proper housekeeping and storage arrangements, helps to reduce the exposure hazards associated with unstable (reactive) materials in a fire or other emergency. As with other chapters of the *International Fire Code*, Section 6602 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapter 67 Water-reactive Solids and Liquids. This chapter addresses the hazards associated with water-reactive materials that are solid or liquid at normal temperatures and pressures. In addition to their water reactivity, these materials may pose a wide range of other hazards, such as toxicity, flammability, corrosiveness or oxidizing potential. This chapter addresses only those materials whose primary hazard is water reactivity. Materials that pose multiple hazards must conform to the requirements of the code with respect to all hazards. Strict compliance with the requirements of this chapter, along with proper housekeeping and storage arrangements, helps to reduce the exposure hazards associated with water-reactive materials in a fire or other emergency. As with other chapters of the *International Fire Code*, Section 6702 contains a list of terms that are defined in Chapter 2 and are applicable to the chapter contents.

Chapters 68 through 79. Reserved for future use.

PART VI—REFERENCED STANDARDS

Chapter 80 Referenced Standards. This code contains several references to standards that are used to regulate materials and methods of construction. Chapter 80 contains a comprehensive list of all standards that are referenced in this code. The standards are part of the code to the extent of the reference to the standard (see Section 102.7). Compliance with the referenced standard is necessary for compliance with this code. By providing specifically adopted standards, the construction and installation requirements necessary for compliance with this code can be readily determined. The basis for code compliance is, therefore, established and available on an equal basis to the code official, contractor, designer and owner.

Chapter 80 is organized in a manner that makes it easy to locate specific standards. It lists all of the referenced standards alphabetically by acronym of the promulgating agency of the standard. Each agency's standards are then listed in either alphabetical or numeric order based upon the standard identification. The list also contains the title of the standard; the edition (date) of the standard referenced; any addenda included as part of the ICC adoption; and the section or sections of this code that reference the standard.

PART VII—APPENDICES

Appendix A Board of Appeals. Deleted.

Appendix B Fire-flow Requirements for Buildings. This appendix provides a tool for the use of jurisdictions in establishing a policy for determining fire-flow requirements in accordance with Section 507.3. The determination of required fire flow is not an exact science, but having some level of information provides a consistent way of choosing the appropriate fire flow for buildings throughout a jurisdiction. The primary tool used in this appendix is a table that presents fire flow based on construction type and building area based on the correlation of the Insurance Services Office (ISO) method and the construction types used in the *International Building Code*. Note that the provisions contained in this appendix are not mandatory unless specifically referenced in the adopting ordinance (see sample ordinance on page xxi).

Appendix C Fire Hydrant Locations and Distribution. This appendix focuses on the location and spacing of fire hydrants, which is important to the success of fire-fighting operations. The difficulty with determining the spacing of fire hydrants is that every situation is unique and has unique challenges. Finding one methodology for determining hydrant spacing is difficult. This particular appendix gives one methodology based on the required fire flow that fire departments can work with to set a policy for hydrant distribution around new buildings and facilities in conjunction with Section 507.5. Note that the provisions contained in this appendix are not mandatory unless specifically referenced in the adopting ordinance (see sample ordinance on page xxi).

Appendix D Fire Apparatus Access Roads. This appendix contains more detailed elements for use with the basic access requirements found in Section 503, which gives some minimum criteria, such as a maximum length of 150 feet and a minimum width of 20 feet, but in many cases does not state specific criteria. This appendix, like Appendices B and C, is a tool for jurisdictions looking for guidance in establishing access requirements and includes criteria for multiple-family residential developments, large one- and two-family subdivisions, specific examples for various types of turn-arounds for fire department apparatus and parking regulatory signage. Note that the provisions contained in this appendix are not mandatory unless specifically referenced in the adopting ordinance (see sample ordinance on page xxi).

Appendix E Hazard Categories. This appendix contains guidance for designers, engineers, architects, code officials, plans reviewers and inspectors in the classifying of hazardous materials so that proposed designs can be evaluated intelligently and accurately. The descriptive materials and explanations of hazardous materials and how to report and evaluate them on a Material Safety Data Sheet (MSDS) are intended to be instructional as well as informative. Note that this appendix is for information purposes and is not intended for adoption.

Appendix F Hazard Ranking. The information in this appendix is intended to be a companion to the specific requirements of Chapters 51 through 67, which regulate the storage, handling and use of all hazardous materials classified as either physical or health hazards. These materials pose diverse hazards, including instability, reactivity, flammability, oxidizing potential or toxicity; therefore, identifying them by hazard ranking is essential. This appendix lists the various hazardous materials categories that are defined in this code, along with the NFPA 704 hazard ranking for each. Note that the provisions contained in this appendix are not mandatory unless specifically referenced in the adopting ordinance (see sample ordinance on page xxi).

Appendix G Cryogenic Fluids—Weight and Volume Equivalents. This appendix gives the fire code official and design professional a ready reference tool for the conversion of the liquid weight and volume of cryogenic fluid to their corresponding volume of gas and vice versa and is a companion to the provisions of Chapter 55 of this code. Note that this appendix is for information purposes and is not intended for adoption.

Appendix H Hazardous Materials Management Plan (HMMP) and Hazardous Materials Inventory Statement (HMIS) Instructions. This appendix is intended to assist businesses in establishing a Hazardous Materials Management Plan (HMMP) and Hazardous Materials Inventory Statement (HMIS) based on the classification and quantities of materials that would be found

on site in storage and/or use. The sample forms and available Material Safety Data Sheets (MSDS) provide the basis for the evaluations. It is also a companion to IFC Sections 407.5 and 407.6, which provide the requirement that the HMIS and HMMP be submitted when required by the fire code official. Note that the provisions contained in this appendix are not mandatory unless specifically referenced in the adopting ordinance (see sample ordinance on page xxi).

Appendix I Fire Protection Systems—Noncompliant Conditions. Deleted.

Appendix J Building Information Sign. This appendix provides design, installation and maintenance requirements for a Building Information Sign (BIS), a fire service tool to be utilized in the crucial, initial response of fire fighters to a structure fire. The BIS placard is designed to be utilized within the initial response time frame of an incident to assist fire fighters in their tactical size-up of a situation as soon as possible after arrival on the scene of a fire emergency. The BIS design is in the shape of a fire service Maltese Cross and includes five spaces (the four wings plus the centerpiece of the cross symbol) in which information is placed about the tactical considerations of construction type and hourly rating, fire protection systems, occupancy type, content hazards and special features that could affect tactical decisions and operations. Note that the provisions contained in this appendix are not mandatory unless specifically referenced in the adopting ordinance (see sample ordinance on page xxi).

Appendix K Construction Requirements for Existing Ambulatory Care Facilities. Deleted.

Appendix L Requirements for Fire Fighter Air Replenishment Systems. This new adoptable appendix provides for the design, installation and maintenance of permanently installed fire fighter breathing air systems in buildings designated by the jurisdiction. Breathing air is critical for fire-fighting operations. Historically, fire departments have supplied air bottles by means of a “bottle brigade,” whereby fire fighters manually transport air bottles up stairways, which is an extraordinarily fire fighter-intensive process and takes fire fighters away from their primary mission of rescue and fire fighting. Technology now exists to address the issue using in-building air supply systems. Fire fighter breathing air systems were introduced in the late 1980s and are now required in a number of communities throughout the United States. The system has been called a “standpipe for air” and consists of stainless steel, high-pressure piping that is supplied by on-site air storage or fire department air supply units. Air filling stations are then strategically located throughout the building allowing fire fighters to refill breathing air cylinders inside the fire building, negating the required “bottle brigade,” and making more fire fighters available for search, rescue and fire suppression operations. Note that the provisions contained in this appendix are not mandatory unless specifically referenced in the adopting ordinance (see sample ordinance on page xxi).

Appendix M High-rise Buildings—Retroactive Automatic Sprinkler Requirement. Deleted.

LEGISLATION

Jurisdictions wishing to adopt the 2015 *International Fire Code* as an enforceable set of regulations for the safeguarding of life and property from fire and explosion hazards arising from the storage, handling and use of hazardous substances, materials and devices, and from conditions hazardous to life or property in the occupancy of buildings and premises should ensure that certain factual information is included in the adopting legislation at the time adoption is being considered by the appropriate governmental body. The following sample adoption legislation addresses several key elements, including the information required for insertion into the code text.

SAMPLE LEGISLATION FOR ADOPTION OF THE *INTERNATIONAL FIRE CODE* ORDINANCE NO. _____

A[N] [ORDINANCE/STATUTE/REGULATION] of the [NAME OF JURISDICTION] adopting the 2015 edition of the *International Fire Code*, regulating and governing the safeguarding of life and property from fire and explosion hazards arising from the storage, handling and use of hazardous substances, materials and devices, and from conditions hazardous to life or property in the occupancy of buildings and premises in the [NAME OF JURISDICTION]; providing for the issuance of permits and collection of fees therefor; repealing [ORDINANCE/STATUTE/REGULATION] No. _____ of the [NAME OF JURISDICTION] and all other ordinances or parts of laws in conflict therewith.

The [GOVERNING BODY] of the [NAME OF JURISDICTION] does ordain as follows:

Section 1. That a certain document, three (3) copies of which are on file in the office of the [TITLE OF JURISDICTION'S KEEPER OF RECORDS] of [NAME OF JURISDICTION], being marked and designated as the *International Fire Code*, 2012 edition, including Appendix Chapters [FILL IN THE APPENDIX CHAPTERS BEING ADOPTED] (see *International Fire Code* Section 101.2.1, 2015 edition), as published by the International Code Council, be and is hereby adopted as the Fire Code of the [NAME OF JURISDICTION], in the State of [STATE NAME] regulating and governing the safeguarding of life and property from fire and explosion hazards arising from the storage, handling and use of hazardous substances, materials and devices, and from conditions hazardous to life or property in the occupancy of buildings and premises as herein provided; providing for the issuance of permits and collection of fees therefor; and each and all of the regulations, provisions, penalties, conditions and terms of said Fire Code on file in the office of the [NAME OF JURISDICTION] are hereby referred to, adopted, and made a part hereof, as if fully set out in this legislation, with the additions, insertions, deletions and changes, if any, prescribed in Section 2 of this ordinance.

Section 2. That the following sections are hereby revised:

Section 101.1. Insert: [NAME OF JURISDICTION]

Section 109.4. Insert: [OFFENSE, DOLLAR AMOUNT, NUMBER OF DAYS]

Section 111.4. Insert: [DOLLAR AMOUNT IN TWO LOCATIONS]

Section 1103.5.3. Insert: [DATE BY WHICH SPRINKLER SYSTEM MUST BE INSTALLED]

Section 3. That the geographic limits referred to in certain sections of the 2015 *International Fire Code* are hereby established as follows:

Section 5704.2.9.6.1 (geographic limits in which the storage of Class I and Class II liquids in above-ground tanks outside of buildings is prohibited): [JURISDICTION TO SPECIFY]

Section 5706.2.4.4 (geographic limits in which the storage of Class I and Class II liquids in above-ground tanks is prohibited): [JURISDICTION TO SPECIFY]

Section 5806.2 (geographic limits in which the storage of flammable cryogenic fluids in stationary containers is prohibited): [JURISDICTION TO SPECIFY]

Section 6104.2 (geographic limits in which the storage of liquefied petroleum gas is restricted for the protection of heavily populated or congested areas): [JURISDICTION TO SPECIFY]

Section 4. That [ORDINANCE/STATUTE/REGULATION] No. _____ of [NAME OF JURISDICTION] entitled [FILL IN HERE THE COMPLETE TITLE OF THE LEGISLATION OR LAWS IN EFFECT AT THE PRESENT TIME SO THAT THEY WILL BE REPEALED BY SPECIFIC REFERENCE] and all other ordinances or parts of laws in conflict herewith are hereby repealed.

Section 5. That if any section, subsection, sentence, clause or phrase of this legislation is, for any reason, held to be unconstitutional, such decision shall not affect the validity of the remaining portions of this ordinance. The **[GOVERNING BODY]** hereby declares that it would have passed this law, and each section, subsection, clause or phrase thereof, irrespective of the fact that any one or more sections, subsections, sentences, clauses and phrases be declared unconstitutional.

Section 6. That nothing in this legislation or in the Fire Code hereby adopted shall be construed to affect any suit or proceeding impending in any court, or any rights acquired, or liability incurred, or any cause or causes of action acquired or existing, under any act or ordinance hereby repealed as cited in Section 4 of this law; nor shall any just or legal right or remedy of any character be lost, impaired or affected by this legislation.

Section 7. That the **[JURISDICTION'S KEEPER OF RECORDS]** is hereby ordered and directed to cause this legislation to be published. (An additional provision may be required to direct the number of times the legislation is to be published and to specify that it is to be in a newspaper in general circulation. Posting may also be required.)

Section 8. That this law and the rules, regulations, provisions, requirements, orders and matters established and adopted hereby shall take effect and be in full force and effect **[TIME PERIOD]** from and after the date of its final passage and adoption.

TABLE OF CONTENTS

<i>Part I—Administrative.</i>	<i>1</i>	307 Open Burning, Recreational Fires and Portable Outdoor Fireplaces	50
CHAPTER 1 SCOPE AND ADMINISTRATION	1	308 Open Flames	51
PART 1—GENERAL PROVISIONS.	1	309 Powered Industrial Trucks and Equipment	53
Section		310 Smoking	53
101 Scope and General Requirements.	1	311 Vacant Premises.	54
102 Applicability.	1	312 Vehicle Impact Protection	55
PART 2—ADMINISTRATIVE PROVISIONS.	2	313 Fueled Equipment	55
103 Department of Fire Prevention.	2	314 Indoor Displays	55
104 General Authority and Responsibilities	3	315 General Storage	56
105 Permits	4	316 Hazards to Fire Fighters.	56
106 Inspections	11	317 Rooftop Gardens and Landscaped Roofs.	57
107 Maintenance	12	318 Laundry Carts.	57
108 Board of Appeals	12	<u>319 Temporary Overflow Shelter.</u>	<u>57</u>
109 Violations	12	<u>320 Group E In Churches, Private Schools and Public Schools.</u>	<u>58</u>
110 Unsafe Buildings	13	CHAPTER 4 EMERGENCY PLANNING AND PREPAREDNESS.	59
111 Stop Work Order (See the provisions of the <i>North Carolina Administrative Code and Policies and applicable North Carolina General Statutes</i>)	13	Section	
112 Service Utilities	13	401 General.	59
113 Fees (Deleted).	13	402 Definitions	59
<u>114 Maintaining a Fire Hazard.</u>	<u>14</u>	403 Emergency Preparedness Requirements	59
<u>115 Local Modification.</u>	<u>14</u>	404 Fire Safety, Evacuation and Lockdown Plans	64
CHAPTER 2 DEFINITIONS	15	405 Emergency Evacuation Drills	65
Section		406 Employee Training and Response Procedures. . . .	66
201 General	15	407 Hazard Communication	67
202 General Definitions	15	<i>Part III—Building and Equipment Design Features . . .</i>	<i>69</i>
<u>203 Occupancy Classifications.</u>	<u>41</u>	CHAPTER 5 FIRE SERVICE FEATURES	69
<i>Part II—General Safety Provisions</i>	<i>49</i>	Section	
CHAPTER 3 GENERAL REQUIREMENTS.	49	501 General.	69
Section		502 Definitions	69
301 General	49	503 Fire Apparatus Access Roads	69
302 Definitions	49	504 Access to Building Openings and Roofs	70
303 Asphalt Kettles	49	505 Premises Identification.	71
304 Combustible Waste Material	49	506 Key Boxes	71
305 Ignition Sources	50	507 Fire Protection Water Supplies	71
306 Motion Picture Projection Rooms and Film.	50	508 Fire Command Center	72
		509 Fire Protection and Utility Equipment Identification and Access.	73
		510 Emergency Responder Radio Coverage	73

TABLE OF CONTENTS

CHAPTER 6 BUILDING SERVICES AND SYSTEMS 77

Section

601	General	77
602	Definitions	77
603	Fuel-fired Appliances	77
604	Emergency and Standby Power Systems	80
605	Electrical Equipment, Wiring and Hazards	82
606	Mechanical Refrigeration	84
607	Elevator Operation, Maintenance and Fire Service Keys	86
608	Stationary Storage Battery Systems	87
609	Commercial Kitchen Hoods	89
610	Commercial Kitchen Cooking Oil Storage	90
611	Hyperbaric Facilities	90

CHAPTER 7 FIRE AND SMOKE PROTECTION FEATURES 91

Section

701	General	91
702	Definitions	91
703	Fire-resistance-rated Construction	91
704	Floor Openings and Shafts	92

CHAPTER 8 INTERIOR FINISH, DECORATIVE MATERIALS AND FURNISHINGS 93

Section

801	General	93
802	Definitions	93
803	Interior Wall and Ceiling Finish and Trim in Existing Buildings	93
804	Interior Wall and Ceiling Trim and Interior Floor Finish in New and Existing Buildings	95
805	Upholstered Furniture and Mattresses in New and Existing Buildings	96
806	Decorative Vegetation in New and Existing Buildings	99
807	Decorative Materials Other than Decorative Vegetation in New and Existing Buildings	99
808	Furnishings Other than Upholstered Furniture and Mattresses or Decorative Materials in New and Existing Buildings	101

CHAPTER 9 FIRE PROTECTION SYSTEMS.... 103

Section

901	General	103
902	Definitions	105
903	Automatic Sprinkler Systems	106
904	Alternative Automatic Fire-extinguishing Systems	113
905	Standpipe Systems	116
906	Portable Fire Extinguishers	119
907	Fire Alarm and Detection Systems	121
908	Emergency Alarm Systems	132
909	Smoke Control Systems	133
910	Smoke and Heat Removal	140
911	Explosion Control	141
912	Fire Department Connections	143
913	Fire Pumps	143
914	Fire Protection Based on Special Detailed Requirements of Use and Occupancy	144
915	Carbon Monoxide <u>Alarm and</u> <u>Detection Systems</u>	147

CHAPTER 10 MEANS OF EGRESS 149

Section

1001	Administration	149
1002	Definitions	149
1003	General Means of Egress	149
1004	Occupant Load	151
1005	Means of Egress Sizing	152
1006	Numbers of Exits and Exit Access Doorways	153
1007	Exit and Exit Access Doorway Configuration	156
1008	Means of Egress Illumination	156
1009	Accessible Means of Egress	157
1010	Doors, Gates and Turnstiles	160
1011	Stairways	168
1012	Ramps	172
1013	Exit Signs	173
1014	Handrails	174
1015	Guards	175
1016	Exit Access	177
1017	Exit Access Travel Distance	178
1018	Aisles	178
1019	Exit Access Stairways and Ramps	179

1020	Corridors	179	2202	Definition	213
1021	Egress Balconies	181	2203	Precautions	213
1022	Exits	181	2204	Explosion Protection	213
1023	Interior Exit Stairways and Ramps	182			
1024	Exit Passageways	184	CHAPTER 23 MOTOR FUEL-DISPENSING		
1025	Luminous Egress Path Markings	184	FACILITIES AND REPAIR		
1026	Horizontal Exits	186	GARAGES	215	
1027	Exterior Exit Stairways and Ramps	186	Section		
1028	Exit Discharge	187	2301	General	215
1029	Assembly	189	2302	Definitions	215
1030	Emergency Escape and Rescue	195	2303	Location of Dispensing Devices	215
1031	Maintenance of the Means of Egress	196	2304	Dispensing Operations	215
			2305	Operational Requirements	216
CHAPTER 11 CONSTRUCTION			2306	Flammable and Combustible Liquid Motor	
REQUIREMENTS FOR				Fuel-dispensing Facilities	217
EXISTING BUILDINGS (Deleted) . . .	197		2307	Liquefied Petroleum Gas Motor	
				Fuel-dispensing Facilities	222
CHAPTERS 12 through 19 RESERVED	199		2308	Compressed Natural Gas Motor	
				Fuel-dispensing Facilities	222
<i>Part IV—Special Occupancies and Operations</i>	<i>201</i>		2309	Hydrogen Motor Fuel-dispensing	
				and Generation Facilities	224
CHAPTER 20 AVIATION FACILITIES	201		2310	Marine Motor Fuel-dispensing Facilities	226
Section			2311	Repair Garages	228
2001	General	201			
2002	Definitions	201	CHAPTER 24 FLAMMABLE FINISHES	231	
2003	General Precautions	201	Section		
2004	Aircraft Maintenance	201	2401	General	231
2005	Portable Fire Extinguishers	202	2402	Definitions	231
2006	Aircraft Fueling	202	2403	Protection of Operations	231
2007	Helistops and Heliports	207	2404	Spray Finishing	233
			2405	Dipping Operations	237
CHAPTER 21 DRY CLEANING	209		2406	Powder Coating	238
Section			2407	Electrostatic Apparatus	239
2101	General	209	2408	Organic Peroxides and	
2102	Definitions	209		Dual-component Coatings	240
2103	Classifications	209	2409	Indoor Manufacturing of	
2104	General Requirements	209		Reinforced Plastics	240
2105	Operating Requirements	209	2410	Floor Surfacing and Finishing Operations	241
2106	Spotting and Pretreating	210			
2107	Dry Cleaning Systems	211	CHAPTER 25 FRUIT AND CROP RIPENING	243	
2108	Fire Protection	211	Section		
			2501	General	243
CHAPTER 22 COMBUSTIBLE DUST-			2502	Definitions	243
PRODUCING OPERATIONS	213		2503	Ethylene Gas	243
Section			2504	Sources of Ignition	243
2201	General	213	2505	Combustible Waste	243

TABLE OF CONTENTS

2506 Ethylene Generators	243
2507 Warning Signs	243

CHAPTER 26 FUMIGATION AND INSECTICIDAL FOGGING..... 245

Section

2601 General	245
2602 Definitions	245
2603 Fire Safety Requirements	245

CHAPTER 27 SEMICONDUCTOR FABRICATION FACILITIES 247

Section

2701 General	247
2702 Definitions	247
2703 General Safety Provisions	247
2704 Storage	251
2705 Use and Handling	253

CHAPTER 28 LUMBER YARDS AND AGRO-INDUSTRIAL, SOLID BIOMASS AND WOODWORKING FACILITIES. ... 257

Section

2801 General	257
2802 Definitions	257
2803 General Requirements	257
2804 Fire Protection	257
2805 Plywood, Veneer and Composite Board Mills	258
2806 Log Storage Areas	258
2807 Storage of Wood Chips and Hogged Material Associated with Timber and Lumber Production Facilities	258
2808 Storage and Processing of Wood Chips, Hogged Material, Fines, Compost, Solid Biomass Feedstock and Raw Product Associated with Yard Waste, Agro-industrial and Recycling Facilities	258
2809 Exterior Storage of Finished Lumber and Solid Biofuel Products	259

CHAPTER 29 MANUFACTURE OF ORGANIC COATINGS..... 261

Section

2901 General	261
--------------------	-----

2902 Definition	261
2903 General Precautions	261
2904 Electrical Equipment and Protection	261
2905 Process Structures	262
2906 Process Mills and Kettles	262
2907 Process Piping	262
2908 Raw Materials in Process Areas	263
2909 Raw Materials and Finished Products	263

CHAPTER 30 INDUSTRIAL OVENS 265

Section

3001 General	265
3002 Definitions	265
3003 Location	265
3004 Fuel Piping	265
3005 Interlocks	265
3006 Fire Protection	265
3007 Operation and Maintenance	265

CHAPTER 31 TENTS AND OTHER MEMBRANE STRUCTURES 267

Section

3101 General	267
3102 Definitions	267
3103 Temporary Tents and Membrane Structures	267
3104 Temporary and Permanent Tents and Membrane Structures	270
3105 Temporary Stage Canopies	272

CHAPTER 32 HIGH-PILED COMBUSTIBLE STORAGE 273

Section

3201 General	273
3202 Definitions	273
3203 Commodity Classification	273
3204 Designation of High-piled Storage Areas	277
3205 Housekeeping and Maintenance	277
3206 General Fire Protection and Life Safety Features	277
3207 Solid-piled and Shelf Storage	279
3208 Rack Storage	280
3209 Automated Storage	280
3210 Specialty Storage	281

CHAPTER 33 FIRE SAFETY DURING CONSTRUCTION AND DEMOLITION	283	3507 Calcium Carbide Systems	291
Section		3508 Acetylene Generators	291
3301 General	283	3509 Piping Manifolds and Hose Systems for Fuel Gases and Oxygen	291
3302 Definitions	283	3510 Hot Work on Flammable and Combustible Liquid Storage Tanks	292
3303 Temporary Heating Equipment	283	CHAPTER 36 MARINAS	293
3304 Precautions against Fire	283	Section	
3305 Flammable and Combustible Liquids	284	3601 Scope	293
3306 Flammable Gases	284	3602 Definitions	293
3307 Explosive Materials	284	3603 General Precautions	293
3308 Owner's Responsibility for Fire Protection	284	3604 Fire Protection Equipment	293
3309 Fire Reporting	285	3605 Marine Motor Fuel-dispensing Facilities	294
3310 Access for Fire Fighting	285	CHAPTER 37 COMBUSTIBLE FIBERS	295
3311 Means of Egress	285	Section	
3312 Water Supply for Fire Protection	285	3701 General	295
3313 Standpipes	285	3702 Definitions	295
3314 Automatic Sprinkler System	285	3703 General Precautions	295
3315 Portable Fire Extinguishers	285	3704 Loose Fiber Storage	295
3316 Motorized Construction Equipment	285	3705 Baled Storage	296
3317 Safeguarding Roofing Operations	286	CHAPTERS 38 through 49 RESERVED	297
CHAPTER 34 TIRE REBUILDING AND TIRE STORAGE	287	<i>Part V—Hazardous Materials</i>	<i>299</i>
Section		CHAPTER 50 HAZARDOUS MATERIALS—GENERAL PROVISIONS	299
3401 General	287	Section	
3402 Definitions	287	5001 General	299
3403 Tire Rebuilding	287	5002 Definitions	301
3404 Precautions against Fire	287	5003 General Requirements	302
3405 Outdoor Storage	287	5004 Storage	316
3406 Fire Department Access	288	5005 Use, Dispensing and Handling	319
3407 Fencing	288	CHAPTER 51 AEROSOLS	323
3408 Fire Protection	288	Section	
3409 Indoor Storage Arrangement	288	5101 General	323
CHAPTER 35 WELDING AND OTHER HOT WORK	289	5102 Definitions	323
Section		5103 Classification of Aerosol Products	323
3501 General	289	5104 Inside Storage of Aerosol Products	323
3502 Definitions	289	5105 Outside Storage	325
3503 General Requirements	289	5106 Retail Display	326
3504 Fire Safety Requirements	289	5107 Manufacturing Facilities	327
3505 Gas Welding and Cutting	290		
3506 Electric Arc Hot Work	291		

TABLE OF CONTENTS

CHAPTER 52 RESERVED329

CHAPTER 53 COMPRESSED GASES.....331

Section

5301 General.....	331
5302 Definitions	331
5303 General Requirements	331
5304 Storage of Compressed Gases	335
5305 Use and Handling of Compressed Gases	335
5306 Medical Gases	335
5307 Carbon Dioxide (CO ₂) Systems Used in Beverage Dispensing Applications	336
5308 Compressed Gases Not Otherwise Regulated	337

CHAPTER 54 CORROSIVE MATERIALS.....339

Section

5401 General.....	339
5402 Definition	339
5403 General Requirements	339
5404 Storage	339
5405 Use	339

CHAPTER 55 CRYOGENIC FLUIDS341

Section

5501 General.....	341
5502 Definitions	341
5503 General Requirements	341
5504 Storage	343
5505 Use and Handling.....	344

CHAPTER 56 EXPLOSIVES AND FIREWORKS347

Section

5601 General.....	347
5602 Definitions	350
5603 Record Keeping and Reporting	351
5604 Explosive Materials Storage and Handling	351
5605 Manufacture, Assembly and Testing of Explosives, Explosive Materials and Fireworks	357
5606 Small Arms Ammunition and Small Arms Ammunition Components	360
5607 Blasting.....	361
5608 Fireworks Display	362
5609 Temporary Storage of Consumer Fireworks	364
5610 Retail Sales of Consumer Fireworks	364

CHAPTER 57 FLAMMABLE AND COMBUSTIBLE LIQUIDS 365

Section

5701 General.....	365
5702 Definitions	365
5703 General Requirements	366
5704 Storage	370
5705 Dispensing, Use, Mixing and Handling.....	390
5706 Special Operations.....	395

CHAPTER 58 FLAMMABLE GASES AND FLAMMABLE CRYOGENIC FLUIDS 407

Section

5801 General.....	407
5802 Definitions	407
5803 General Requirements	407
5804 Storage	408
5805 Use	408
5806 Flammable Cryogenic Fluids.....	408
5807 Metal Hydride Storage Systems.....	409
5808 Hydrogen Fuel Gas Rooms	410

CHAPTER 59 FLAMMABLE SOLIDS 413

Section

5901 General.....	413
5902 Definitions	413
5903 General Requirements	413
5904 Storage	413
5905 Use	413
5906 Magnesium.....	413

CHAPTER 60 HIGHLY TOXIC AND TOXIC MATERIALS 415

Section

6001 General.....	415
6002 Definitions	415
6003 Highly Toxic and Toxic Solids and Liquids	415
6004 Highly Toxic and Toxic Compressed Gases	416
6005 Ozone Gas Generators	421

CHAPTER 61 LIQUEFIED PETROLEUM GASES 423

Section

6101 General.....	423
6102 Definitions	423

6103	Installation of Equipment (<u>Deleted</u>)	423	CHAPTER 66 UNSTABLE	
6104	Location of LP-gas Containers (<u>Deleted</u>)	423	(REACTIVE) MATERIALS	439
6105	Prohibited Use of LP-gas (<u>Deleted</u>)	423	Section	
6106	Dispensing and Overfilling (<u>Deleted</u>)	423	6601 General	439
6107	Safety Precautions and Devices (<u>Deleted</u>)	423	6602 Definition	439
6108	Fire Protection (<u>Deleted</u>)	423	6603 General Requirements	439
6109	Storage of Portable LP-gas Containers		6604 Storage	439
	Awaiting Use or Resale (<u>Deleted</u>)	423	6605 Use	440
6110	LP-gas Containers Not in Service (<u>Deleted</u>)	423	CHAPTER 67 WATER-REACTIVE	
6111	Parking and Garaging of		SOLIDS AND LIQUIDS	441
	LP-gas Tank Vehicles (<u>Deleted</u>)	423	Section	
CHAPTER 62 ORGANIC PEROXIDES		425	6701 General	441
Section			6702 Definition	441
6201 General	425		6703 General Requirements	441
6202 Definition	425		6704 Storage	441
6203 General Requirements	425		6705 Use	442
6204 Storage	425		CHAPTERS 68 through 79 RESERVED	443
6205 Use	427		<i>Part VI—Referenced Standards</i>	<i>445</i>
CHAPTER 63 OXIDIZERS, OXIDIZING			CHAPTER 80 REFERENCED STANDARDS	445
GASES AND OXIDIZING			<i>Part VII—Appendices</i>	<i>457</i>
CRYOGENIC FLUIDS		429	APPENDIX A BOARD OF APPEALS (<u>Deleted</u>)	457
Section			APPENDIX B FIRE-FLOW REQUIREMENTS	
6301 General	429		FOR BUILDINGS	459
6302 Definitions	429		Section	
6303 General Requirements	429		B101 General	459
6304 Storage	430		B102 Definitions	459
6305 Use	431		B103 Modifications	459
6306 Liquid Oxygen in Home Health Care	431		B104 Fire-flow Calculation Area	459
CHAPTER 64 PYROPHORIC MATERIALS		435	B105 Fire-flow Requirements for Buildings	459
Section			B106 Referenced Standards	461
6401 General	435		APPENDIX C FIRE HYDRANT LOCATIONS	
6402 Definition	435		AND DISTRIBUTION	463
6403 General Requirements	435		Section	
6404 Storage	435		C101 General	463
6405 Use	436		C102 Number of Fire Hydrants	463
CHAPTER 65 PYROXYLIN (CELLULOSE			C103 Fire Hydrant Spacing	463
NITRATE) PLASTICS		437	C104 Consideration of Existing Fire Hydrants	463
Section			C105 Referenced Standards	464
6501 General	437			
6502 Definitions	437			
6503 General Requirements	437			
6504 Storage and Handling	437			

TABLE OF CONTENTS

**APPENDIX D FIRE APPARATUS
ACCESS ROADS 465**

Section

D101 General 465

D102 Required Access 465

D103 Minimum Specifications 465

D104 Commercial and Industrial Developments 466

D105 Aerial Fire Apparatus Access Roads 466

D106 Multiple-family Residential Developments 467

D107 One- or Two-family Residential
Developments 467

D108 Referenced Standards 467

APPENDIX E HAZARD CATEGORIES 469

Section

E101 General 469

E102 Hazard Categories 469

E103 Evaluation of Hazards 473

E104 Referenced Standards 474

APPENDIX F HAZARD RANKING 475

Section

F101 General 475

F102 Referenced Standards 475

**APPENDIX G CRYOGENIC FLUIDS—
WEIGHT AND VOLUME
EQUIVALENTS 477**

Section

G101 General 477

**APPENDIX H HAZARDOUS MATERIALS
MANAGEMENT PLAN (HMMP)
AND HAZARDOUS MATERIALS
INVENTORY STATEMENT (HMIS)
INSTRUCTIONS 479**

Section

H101 HMMP 479

H102 HMIS 479

H103 Emergency Plan 480

H104 Referenced Standards 480

**APPENDIX I FIRE PROTECTION
SYSTEMS—NONCOMPLIANT
CONDITIONS (Deleted) 487**

**APPENDIX J BUILDING INFORMATION
SIGN 489**

Section

J101 General 489

J102 Referenced Standards 491

**APPENDIX K CONSTRUCTION
REQUIREMENTS FOR
EXISTING AMBULATORY
CARE FACILITIES (Deleted) 493**

**APPENDIX L REQUIREMENTS FOR
FIRE FIGHTER AIR
REPLENISHMENT SYSTEMS 495**

Section

L101 General 495

L102 Definitions 495

L103 Permits 495

L104 Design and Installation 495

L105 Acceptance Tests 497

L106 Inspection, Testing and Maintenance 497

L107 Referenced Standards 497

**APPENDIX M HIGH-RISE BUILDINGS—
RETROACTIVE AUTOMATIC
SPRINKLER
REQUIREMENT (Deleted) 499**

INDEX 501